


P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

11 July 2023

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2023 Quarter 2 (April – June)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 April 2023 through 30 June 2023.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink that appears to read "Katherine Dietz".

Katherine Dietz, P.E.
Director of Utilities

Enclosures

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
4/5/2023	12:40:51 PM	4/5/2023	1:20:55 PM	Vineyard Ave & Lake Placid Rd, Tyler, TX 75701	SS.GM.T0000928	West Mud Creek	800	650	MANHOLE	DEBRIS FATS, OIL, GREASE ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
4/17/2023	2:00:04 PM	4/17/2023	3:15:10 PM	113 N Northwest Loop 323, Tyler, TX 75702	SS.GM.T0006562	Contained in Yard	375	300	GRAVITY MAIN	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
4/19/2023	12:00:00 PM	4/19/2023	6:00:00 PM	609 Fair Park Dr, Tyler, TX 75702	SS.GM.T0007199	Willow Creek	7,200	2000	PRIVATE CLEANOUT	VANDALISM	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Removed Obstruction from Main	No
4/27/2023	8:50:16 PM	4/27/2023	9:30:25 PM	Clinic Dr & S Fleishel Ave, Tyler, TX 75701	SS.GM.T0009378	Contained in Yard	80	50	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Coordinate with Pre-Treatment and Cleaned to Remove Scaling	No
4/29/2023	9:00:34 AM	4/29/2023	10:10:47 AM	Clinic Dr & Foundation Dr, Tyler, TX 75701	SS.GM.T0014216	Contained in Yard	210	140	GRAVITY MAIN	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Coordinate with Pre-Treatment and Place on High Frequency Cleaning List	No
4/29/2023	3:50:19 PM	4/29/2023	4:40:00 PM	Medical Dr & S Fleishel Ave, Tyler, TX 75701	SS.GM.T0009378	Contained in Yard	50	35	MANHOLE	FATS, OIL, GREASE	No	Yes, 4/27/2023	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Coordinate with Pre-Treatment and Place on High Frequency Cleaning List	No
5/15/2023	12:05:39 PM	5/15/2023	12:35:46 PM	1811 Ricketty Ln, Tyler, TX 75703	SS.GM.T0013377	Contained in Storm Drain	60	50	MANHOLE	SCALING OF METALLIC PIPE	No	Yes, 3/26/2018	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Cleaned to Remove Scaling	No
5/23/2023	11:00:21 AM	5/23/2023	1:30:27 PM	1102 W Gentry Pkwy, Tyler, TX 75702	SS.GM.T0008238	Contained in Storm Drain	300	190	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Removed Obstruction from Main	No
6/6/2023	3:15:01 PM	6/6/2023	4:45:07 PM	3200 S Southwest Loop 323, Tyler, TX 75701	SS.GM.T0003657	Contained in Yard	120	50	MANHOLE	DEBRIS FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
6/27/2023	1:00:21 PM	6/27/2023	1:15:00 PM	14352 FM 2964, Tyler, TX 75791	SS.MH.T0016586	Contained in Yard	30	5	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Removed Obstruction from Main	No
6/30/2023	11:15:45 AM	6/30/2023	11:45:49 AM	8010 Hollytree Dr, Tyler, TX 75703	SS.GM.T0014060	Contained in Yard	300	260	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Added Signage for Main Location	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.


Katherine Dietz, P.E. - Director of Utilities

7/11/23
Date