


P. O. Box 2039  
Tyler, Texas 75710



511 W Locust  
Tyler, Texas 75702

17 October 2023

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087


Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-1-09767  
Quarterly Report – 2023 Quarter 3 (July – September)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 July 2023 through 30 September 2023.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

  
Katherine Dietz, P.E.  
Director of Utilities

Enclosures

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from which SSO was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/vessel	Comments/Response	Follow-Up Actions	Public Notification Made?
7/7/2023	8:30:37 AM	7/7/2023	11:00:42 AM	1915 W Ewin St, Tyler, TX 75702	SS GM T0006731	Willow Creek	1500	1350	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Repair Sewer Main	No
7/28/2023	5:15:50 PM	7/28/2023	5:30:54 PM	1908 E Ewin St, Tyler, TX 75702	SS GM T0004254	Contained in Parking Lot	150	130	PRIVATE CLEANOUT	PIPE TUBERCULATION	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Main to be Replaced or Lined	No
8/1/2023	3:47:24 PM	8/1/2023	4:17:28 PM	117 S Thompson Ave, Tyler, TX 75702	SS GM T0005846	Contained in Street	90	75	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Hold Contractors Responsible for Repair	No
8/4/2023	2:25:03 PM	8/4/2023	4:45:08 PM	Rachel Ave, Tyler, TX 75701	SS GM T0007393	Indian Creek	700	700	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Main to be Replaced or Lined	No
8/16/2023	9:15:02 AM	8/16/2023	10:15:07 AM	2400 Pleasant Dr, Tyler, TX 75701	SS GM T0005716	Black Fork Creek	300	0	MANHOLE	DEBRIS	No	No	Main Jetted. Blockage Cleared. Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
8/17/2023	7:45:18 AM	8/17/2023	8:00:23 AM	6101 Sutherland Dr., Tyler, TX 75703	SS GM T0001483	Contained in Street	10	6	MANHOLE	DEBRIS	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Monitor Manhole for Early Action Cleaning	No
8/17/2023	4:00:47 PM	8/17/2023	4:40:00 PM	1321 Doctors Dr, Tyler, TX 75701	SS GM T0008895	Black Fork Creek	600	500	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
8/19/2023	10:00:03 AM	8/19/2023	12:30:00 PM	W Barrett St & N Grand Ave, Tyler, TX 75702	SS GM T0008238	Black Fork Creek	450	400	GRAVITY MAIN	BREAKS, OTHER CAUSES	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Repair Sewer Main	No
8/21/2023	10:00:00 AM	8/21/2023	11:15:00 AM	5521 Old Bullard Rd, Tyler, TX 75703	SS GM T0014549	West Mud Creek	750	500	MANHOLE	DEBRIS	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
8/30/2023	10:00:00 AM	8/30/2023	1:00:00 PM	1326 Bright Star Ct, Tyler, TX 75703	SS GM T0011250	W Mud Creek	900	600	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
9/8/2023	8:20:56 PM	9/8/2023	8:50:00 PM	118 S Fleischel Ave, Tyler, TX 75702	SS GM T0006134	Contained in Street	90	75	MANHOLE	DEBRIS	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
9/20/2023	2:00:00 PM	9/21/2023	2:00:00 PM	Centennial Pkwy & Market Square Blvd, Tyler, TX 75703	SS GM T0012211	Shackelford Creek	36000	25000	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Repaired Manhole/Invert	No
9/23/2023	12:00:00 PM	9/23/2023	1:00:00 PM	8337 Lakeway Dr, Tyler, TX 75703	SS GM T0011266	Contained in Field	300	250	MANHOLE	DEBRIS	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Place on High Frequency Cleaning List	No
9/30/2023	11:00:00 AM	9/30/2023	11:40:00 AM	3408 Shady Trails Dr, Tyler, TX 75702	SS GM T0007983	Contained in Yard	40	20	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted. Overflow Vacuumed. Overflow Stopped. Area	Repair Sewer Main	No

**CERTIFICATION:**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

  
Katherine Dietz, P.E. - Director of Utilities

10/18/2023  
Date