


P.O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

10 April 2024

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2024 Quarter 1 (January – March)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 January 2024 through 31 March 2024.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in black ink that appears to read "Kate M. Dietz".


Kate Dietz, P.E.
Director of Utilities

Enclosures

Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
800 Woodhall Pl, 75703	SS.GM.T0003767	West Mud Creek	300		GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair sewer main	No
528 Victory Dr, 75701	SS.GM.T0006183 SS.GM.T0009188	Black Fork Creek	360	0	MANHOLE	Flooding	No	Yes, 12/23/2017 & 12/27/16	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Monitor Sewer Main	No
2120 E Southeast Loop 323, 75701	SS.GM.T0001248	Contained	150	125	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Manhole Invert	No
457 E Rieck Rd, 75703	SS.GM.T0001957	West Mud Creek	900	600	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
800 Moorehill Dr, 75701	SS.GM.T0004295	West Mud Creek	900	600	GRAVITY MAIN	Roots	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No
2828 W Northwest Loop 323	SS.GM.T0012799	Contained	30	15	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
1038 S Fleishel Ave, 75701	SS.GM.T0015561	Contained	60	40	MANHOLE	Debris	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Repair sewer main, major offset	No
10390 Spur 164, 75709	SS.FM.T0000042	Indian Creek	30000	20000	FORCE MAIN	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Force Main	No
413 Hollyoak Dr, 75703	SS.GM.T0003214	Contained	15	0	PRIVATE CLEANOUT	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
7925 S Broadway Ave, 75703	SS.GM.T0010379	West Mud Creek	60	30	MANHOLE	Debris	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
E 5th St & Old Omen Rd	SS.GM.T0015922	Black Fork Creek	630	450	MANHOLE	Roots	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No
504 E 6th St, 75701	SS.GM.T0006248	Contained	150	120	MANHOLE	Debris	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
3274 Professional Dr, 75701	SS.GM.T0000956	West Mud Creek	250	220	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List & Refer to Pre-Treatment	No
1712 Pine Crest Dr, 75701	SS.GM.T0004381	Black Fork Creek	1260	876	MANHOLE	BREAKS, OTHER CAUSES	No	Yes, 5/24/2017, 6/17/2017 & 9/8/2017	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
Old Bullard Rd & Rudman Rd	SS.GM.T0012991	West Mud Creek	540	400	MANHOLE	Debris	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
5315 S Broadway Ave	SS.GM.T0002424	Contained	30	20	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.



04-10-24

Kate Dietz, P.E. - Director of Utilities

Date