


P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

16 July 2023

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087


Re: City of Tyler Consent Decree
DOJ No. 90-5-1-09767
Quarterly Report – 2024 Quarter 2 (April – June)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 April 2024 through 30 June 2024.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,


Katherine Dietz, P.E.
Director of Utilities


Enclosures

City of Tyler Consent Decree,
DOJ No. 90-5-1-09767
Quarterly Report - 2024 Quarter 2
01 April 2024 through 30 June 2024

Start Date	Start Time	Finish Date	Finish Time	Address/Location		Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
4/3/2024	1:00:00 PM	4/3/2024	2:00:00 PM	2388 W Cumberland Rd, Tyler, TX 75703		SS.FM.T0000085	Contained in Yard	300	250	FORCE MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
4/4/2024	11:00:17 AM	4/4/2024	12:30:38 PM	6200 Villa Rosa Way, Tyler, TX 75707		SS.GM.T0016532	Contained in Yard	90	70	MANHOLE	CONTRACTOR DAMAGE VANDALISM	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Repair Manhole/Invert	No
4/11/2024	4:30:00 PM	4/11/2024	7:50:00 PM	620 W Cumberland Rd, Tyler, TX 75703		SS.MH.T0000434	West Mud Creek	11,000	0	MANHOLE	EQUIPMENT MALFUNCTION	No	Yes	Installed Bypass Pump, Overflow Vacuumed, Overflow Stopped, Area Disinfected	Other: Repair Pump	No
4/26/2024	11:30:00 AM	4/26/2024	12:00:00 PM	1812 E Southeast Loop 323, Tyler, TX 75701		SS.GM.T0001240	Contained in Yard	30	20	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Reconnected Customer Service Lateral	Other: Connected Customer Service Lateral	No
4/29/2024	2:30:00 PM	4/30/2024	5:30:00 AM	10140 C R 1125, Tyler, TX 75709		SS.FM.T0000042	Indian Creek	22,500	12,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Force Main	Line Scheduled for Sliplining	No
5/1/2024	11:20:42 AM	5/1/2024	11:46:05 AM	1901 Ricketty Ln, Tyler, TX 75703		SS.GM.T0001222	Contained in Parking Lot	78	50	PRIVATE CLEANOUT	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	Yes
5/4/2024	8:45:46 PM	5/4/2024	8:55:09 PM	Ricketty Ln & Paluxy Dr, Tyler, TX 75703		SS.GM.T0013367	Contained in Street	100	90	MANHOLE	DEBRIS	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List; Scheduled to be Replaced	No
5/17/2024	8:20:00 PM	5/17/2024	8:50:29 PM	Rudman Rd & Sherry Ln, Tyler, TX 75701		SS.GM.T0000618	West Mud Creek	100	25	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
5/18/2024	7:00:00 PM	5/18/2024	7:30:37 PM	N Confederate Ave & W Gentry Pkwy, Tyler, TX 75702		SS.GM.T0006372	Contained in Street	30	20	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
5/21/2024	5:00:00 PM	5/22/2024	1:30:00 PM	915 S Southwest Loop 323, Tyler, TX 75703		SS.GM.T0007771	Indian Creek	3,300	2,000	GRAVITY MAIN	BREAKS DUE TO EROSION BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
6/3/2024	2:00:00 PM	6/3/2024	3:30:00 PM	4331 Mark Hayes Ct, Tyler, TX 75709		SS.GM.T0000240	Indian Creek	3,600	0	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
6/3/2024	10:30:00 PM	6/4/2024	4:00:00 AM	14939 C R 46, Tyler, TX 75704		SS.LS.T0000016	Black Fork Creek	3,953,070	0	LIFT STATION	EQUIPMENT MALFUNCTION-POWER OUTAGE	No	No	Set Up Generator and Restored Power	Other: Repair Power Line	Yes
6/12/2024	7:30:00 AM	6/12/2024	2:30:41 PM	10383 Spur 164, Tyler, TX 75709		SS.FM.T0000042	Indian Creek	14,000	8,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes	Set Up Bypass Pumping by Vactor Trucks, Overflow Contained, Overflow Vacuumed, Area Disinfected, Repaired Force Main	Line Scheduled for Sliplining	No
6/13/2024	11:00:41 AM	6/13/2024	2:30:49 PM	716 W Queen St, Tyler, TX 75702		SS.GM.T0007863	Black Fork Creek	5,250	4,500	GRAVITY MAIN	BREAKS, OTHER CAUSES	No	No	Set Up Bypass Pumping, Overflow Vacuumed, Area Disinfected, Repaired Sewer Main	Repair Sewer Main	No
6/19/2024	12:40:00 PM	6/19/2024	3:40:00 PM	10390 Greenbriar Rd, Tyler, TX 75709		SS.FM.T0000042	Indian Creek	18,000	10,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Force Main	Line Scheduled for Sliplining	No
6/28/2024	2:00:00 PM	6/28/2024	2:40:35 PM	10486 Spur 164, Tyler, TX 75709		SS.FM.T0000042	Indian Creek	2,000	2,000	FORCE MAIN	EQUIPMENT MALFUNCTION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Force Main	Line Scheduled for Sliplining	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.


Katherine Dietz, P.E. - Director of Utilities

7-16-24

Date