


P. O. Box 2039  
Tyler, Texas 75710



511 W Locust  
Tyler, Texas 75702

23 October 2023

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087

Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-109767  
Quarterly Report – 2024 Quarter 3 (July-September)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 July 2024 through 30 September 2024.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Katherine Dietz".

Katherine Dietz, P.E.  
Director of Utilities

Enclosures

**City of Tyler Consent Decree,  
DOJ No. 90-5-1-09767  
Quarterly Report - 2024 Quarter 3  
01 July 2024 through 30 September 2024**

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeal SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
8/5/2024	8:30:00 AM	8/5/2024	10:30:00 AM	2301 Debby Dr TX, 75701	Tyler, SS.GM.T0005695	Black Fork Creek	120	80	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
8/7/2024	2:15:15 PM	8/7/2024	3:15:00 PM	1007 N Northwest Loop 323 Tyler, TX, 75702	SS.GM.T0013190	Contained in Yard	600	400	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Added to HFCP	No
8/8/2024	8:30:00 AM	8/8/2024	9:30:00 AM	10886 Spur 164 TX, 75709	Tyler, SS.FM.T0000042	Indian Creek	9,000	7,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
8/17/2024	3:00:00 PM	8/17/2024	3:45:26 PM	10539 Spur 164 TX, 75709	Tyler, SS.FM.T0000042	Contained in Street	90	90	FORCE MAIN	EQUIPMENT MALFUNCTION	No	No	Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Control Valve	Repaired Control Valve	No
8/21/2024	7:30:00 AM	8/21/2024	12:30:00 PM	10886 Spur 164 TX, 75709	Tyler, SS.GM.T0012447	Indian Creek	4,500	0	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
8/30/2024	7:30:58 AM	8/30/2024	9:30:05 AM	1022 Claude St TX, 75702	Tyler, SS.GM.T0005251	Black Fork Creek	3,600	1500	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
9/28/2024	1:30:00 PM	9/28/2024	5:00:00 PM	2266 W Cumberland Rd TX, 75703	Tyler, SS.FM.T0000085	Indian Creek	30	25	FORCE MAIN	EQUIPMENT MALFUNCTION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Cleaned ARV	No

**CERTIFICATION:**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Katherine Dietz, P.E. Director of Utilities*

*10-28-24*