

P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

22 January 2025

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2024 Quarter 4 (October-December)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 October 2024 through 31 December 2024.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Katherine Dietz'.

Katherine Dietz, P.E.
Director of Utilities

Enclosures

City of Tyler Consent Decree,
DOJ No. 90-5-1-1-09767
Quarterly Report - 2024 Quarter 4
01 October 2024 through 31 December 2024

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repair SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
10/9/2024	10:00:00 AM	10/9/2024	1:00:00 PM	2400 Pleasant Dr., 75701 Tyler, TX	SS.GM.T0004635	Black Fork Creek	5,400	2,000	GRAVITY MAIN	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
10/11/2024	9:00:00 AM	10/11/2024	3:30:00 PM	6801 S Broadway Ave., 75703 Tyler, TX	SS.GM.T0013361	West Mud Creek	1,950	500	MANHOLE	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Repair Manhole/Invert	No
10/11/2024	10:00:28 AM	10/17/2024	10:15:32 AM	1136 E Lake St., 75701 Tyler, TX	SS.GM.T0009034	Contained in Yard	30	25	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Blockage (Wipes) Removed	No
10/29/2024	2:55:00 PM	10/29/2024	4:55:00 PM	1733 Richards St., TX, 75702 Tyler, TX	SS.GM.T0008026	Black Fork Creek	1,200	1,000	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
11/7/2024	10:00:04 AM	11/7/2024	11:00:09 AM	1224 Neches Dr., 75702 Tyler, TX	SS.MH.T0001117	Contained in Yard	60	60	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Service (Service Connection)	No
11/10/2024	5:30:00 PM	11/10/2024	7:30:00 PM	10539 Spur 164, 75709 Tyler, TX	SS.FM.T0000942	Contained in Yard	12,000	0	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
11/11/2024	2:30:00 PM	11/11/2024	7:30:00 PM	1224 Winona Ave., Tyler, TX 75702	SS.GM.T0008420	Black Fork Creek	600	500	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
11/14/2024	3:45:00 PM	11/14/2024	4:30:00 PM	1201 E Lawrence St., 75702 Tyler, TX	SS.GM.T0004203	Black Fork Creek	225	100	MANHOLE	DEBRIS FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Repair Manhole/Invert	No
12/17/2024	2:30:04 PM	12/17/2024	6:45:15 PM	Edinburgh Dr & Shiloh Rd, Tyler, TX 75703	SS.GM.T0001699	West Mud Creek	1,500	200	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
12/21/2024	2:45:27 PM	12/21/2024	6:15:00 PM	6100 Hollytree Dr., 75703 Tyler, TX	SS.MH.T0004102	West Mud Creek	1,050	800	MANHOLE	EQUIPMENT MALFUNCTION (Contractor Bypass Pumping)	No	No	Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Review & Monitor Contractor Bypass Pumping	No
12/23/2024	1:00:00 PM	12/28/2024	5:30:18 PM	3953 Lake Forest Dr., 75707 Tyler, TX	SS.GM.T0002593	Galley Creek	2,700	500	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repair Sewer Main	Repair Sewer Main	No
12/30/2024	12:30:26 PM	12/30/2024	2:00:29 PM	E Gold St & N Spring Ave., Tyler, TX 75702	SS.GM.T0005169	Contained in Street	180	150	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Blockage (Construction Material) Removed	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.


Katherine Dietz, P.E., Director of Utilities
Date 1/23/25