


P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

30 April 2025

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2025 Quarter 1 (January – March)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 January 2025 through 31 March 2025.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

Katherine Dietz, P.E.
Director of Utilities

Enclosures

**City of Tyler Consent Decree,
DOJ No. 90-5-1-09767
Quarterly Report - 2025 Quarter 1
01 January 2025 through 31 March 2025**

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
1/2/2025	3:00:00 PM	1/2/2025	3:20:00 PM	908 Hospital Dr. Tyler, TX 75701	SS.GM.T0009378	Contained	200	150	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Addressed by Pretreatment FOG Program	No
1/13/2025	8:45:53 AM	1/13/2025	9:15:59 AM	325 S Bois D Arc Ave, Tyler, TX 75702	SS.GM.T0009085	Contained	150	125	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/19/2025	12:20:52 PM	1/19/2025	1:20:57 PM	7750 Morning Star Dr. Tyler, TX 75703	SS.GM.T0010551	Contained	300	270	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Addressed by Pretreatment FOG Program	No
1/26/2025	8:00:00 PM	1/26/2025	9:00:00 PM	414 E Southeast Loop 223, Tyler, TX 75701	SS.GM.T0008546	Contained	600	500	MANHOLE	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Repaired Sewer Main	No
1/31/2025	8:45:30 AM	1/31/2025	9:45:34 AM	Dinah Ln & De Charles St, Tyler, TX 75701	SS.GM.T0002685	Contained	60	50	MANHOLE	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/31/2025	8:15:02 AM	1/31/2025	10:15:15 AM	1129 Pollard Dr, Tyler, TX 75701	SS.GM.T000407	West Mud Creek	240	20	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Repaired Manhole	No
2/2/2025	1:00:59 PM	2/2/2025	2:30:00 PM	418 S Southwest Loop 323, Tyler, TX 75702	SS.GM.T0015346	Contained	180	100	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Place on High Frequency Cleaning list	No
2/5/2025	8:45:46 AM	2/5/2025	9:15:49 AM	E 5th St & Old Omen Rd Tyler, TX 75701	SS.GM.T0015922	Black Fork Creek	150	120	MANHOLE	ROOTS	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
2/5/2025	7:00:00 PM	2/5/2025	7:45:39 PM	900 Baxter Ave, Tyler, TX 75701	SS.GM.T0004237	Contained	90	90	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Addressed by Pretreatment FOG Program	No
2/17/2025	9:30:18 AM	2/17/2025	10:00:21 AM	3700 McDonald Rd. Tyler, SS.GM.T0005482	SS.GM.T0005482	Gilley Creek	900	750	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
2/17/2025	7:00:00 PM	2/17/2025	9:00:00 PM	506 Rice Rd, Tyler, TX 75703	SS.GM.T0001026	Contained	240	150	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
3/5/2025	11:50:03 AM	3/5/2025	12:20:08 PM	724 S Southeast Loop 323, Tyler, TX 75707	SS.GM.T0008682	Black Fork Creek	300	260	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
3/5/2025	1:45:54 PM	3/5/2025	2:30:59 PM	Patony Dr & Sybill Ln, Tyler, TX 75703	SS.GM.T0001760	West Mud Creek	450	375	MANHOLE	CONTRACTOR DAMAGE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Removed Obstruction from Main	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person or persons who manage this system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

Katherine Dietz, P. E., Director of Utilities

4/30/25