


P. O. Box 2039  
Tyler, Texas 75710



511 W. Locust  
Tyler, Texas 75702

14 July 2025

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087

Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-1-09767  
Quarterly Report – 2025 Quarter 2 (April – June)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 April 2025 through 30 June 2025.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink that appears to read "Katherine Dietz, P.E." The signature is fluid and cursive, with "Katherine" and "Dietz" being the most distinct parts.

Katherine Dietz, P.E.  
Director of Utilities

Enclosures

**City of Tyler Consent Decree,  
DOJ No. 90-5-1-09767  
Quarterly Report - 2025 Quarter 2  
01 April 2025 through 30 June 2025**

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety of the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
4/2/2025	1:15:50 PM	4/2/2025	2:15:55 PM	772 W Cumberland Rd, TX, 75703	SS.MH.T0000434	West Mud Creek	9000	0	MANHOLE	EQUIPMENT MALFUNCTION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole	Equipment Scheduled for Repair	No
4/5/2025	3:15:15 PM	4/5/2025	3:45:18 PM	Paluxy Dr & E Southeast Loop 323, TX, 75701	SS.GM.T0001236	West Mud Creek	300	300	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Add to HFCP	No
4/7/2025	10:30:00 AM	4/7/2025	3:30:00 PM	772 W Cumberland Rd, TX, 75703	SS.GM.T0011236	West Mud Creek	40,500	5000	GRAVITY MAIN	BREAKS DUE TO EROSION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Scheduled Line to be Replaced or Lined	No
4/16/2025	11:20:00 AM	4/16/2025	3:20:00 PM	1909 Shiloh Rd, 75703	SS.GM.T0001373	West Mud Creek	9500	2000	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repaired Sewer Main & Scheduled Line to be Replaced or Lined	No
5/8/2025	10:00:00 PM	5/8/2025	10:30:00 PM	1823 Old Oman Rd, 75701	SS.GM.T0008750	Contained	150	100	PRIVATE CLEANOUT	VANDALISM	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Advised Contractor and Inspector to monitor	No
5/20/2025	11:30:00 AM	5/20/2025	12:30:00 PM	6784 S Broadway Ave, 75703	SS.GM.T0002005	Contained	180	160	PRIVATE CLEANOUT	DEBRIS, FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Refer to Pre-Treatment	No
5/23/2025	12:00:00 PM	5/23/2025	4:30:31 PM	2623 Boldt Ave, 75701	SS.GM.T0005742	Black Fork Creek	1350	0	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Scheduled Line to be Replaced or Lined	No
5/27/2025	1:50:00 PM	5/27/2025	2:20:00 PM	S Fleischel Ave & Osler Dr	SS.GM.T0016394	Contained	150	120	MANHOLE	DEBRIS	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Add to HFCP	No
6/4/2025	5:20:00 PM	6/4/2025	5:55:00 PM	620 W Cumberland Rd, 75703	SS.MH.T0007857	Contained	7000	2000	MANHOLE	EXCESSIVE INFLOW	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected	I&I Reduction through Private Lateral Program Remedial Repairs	No
5/26/2025	11:05:00 AM	5/26/2025	12:21:00 PM	14939 C R 46, TX, 75704	SS.LS.T000016	Black Fork Creek	7600	0	LIFT STATION	EQUIPMENT MALFUNCTION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Power Restored	Equipment Repaired	No
5/26/2025	6:50:00 AM	5/26/2025	8:00:00 AM	620 W Cumberland Rd, 75703	SS.MH.T0014433	Contained	36400	0	MANHOLE	POWER FAILURE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Power Restored	Restore Power	Yes
6/11/2025	10:50:00 AM	6/11/2025	2:10:00 PM	1909 Shiloh Rd, 75703	SS.GM.T0009700	West Mud Creek	800	0	GRAVITY MAIN	BREAKS DUE TO EROSION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Scheduled Line to be Replaced or Lined	No
6/11/2025	2:00:21 PM	6/11/2025	2:45:28 PM	620 W Cumberland Rd, 75703	SS.MH.T0007857	Contained	6750	1000	MANHOLE	EXCESSIVE INFLOW	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	I&I Reduction through Private Lateral Program Remedial Repairs	No
6/12/2025	9:00:56 AM	6/12/2025	9:30:00 AM	2321 Sunnybrook Dr, 75701	SS.GM.T0014343	West Mud Creek	1020	260	MANHOLE	EXCESSIVE INFLOW	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected	I&I Reduction through Private Lateral Program Remedial Repairs	No
6/12/2025	9:40:38 AM	6/12/2025	10:00:00 AM	772 W Cumberland Rd, TX, 75703	SS.MH.T0007095	Contained	3000	0	MANHOLE	EQUIPMENT MALFUNCTION	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Power Restored	Equipment Scheduled for Repair	No
6/18/2025	9:00:57 AM	6/18/2025	12:00:00 PM	Edinburgh Dr & Shiloh Rd, TX, 75703	SS.GM.T0003080	Contained	180	180	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
6/18/2025	10:00:19 AM	6/18/2025	12:00:00 PM	4917 Thistle Dr, 75703	SS.GM.T0001666	West Mud Creek	600	550	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	Yes

**CERTIFICATION:**  
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

*Katherine Dietz, P.E. - Director of Utilities*

*7/14/2025*