


P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

15 October 2025

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2025 Quarter 3 (July-September)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 July 2025 through 30 September 2025.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink that reads "Katherine Dietz, P.E." The signature is fluid and cursive, with "Katherine" and "Dietz" being the most prominent parts.

Katherine Dietz, P.E.
Director of Utilities

Enclosures

**City of Tyler Consent Decree,
DOJ No. 90-5-1-1-09767
Quarterly Report - 2025 Quarter 3
01 July 2025 through 30 September 2025**

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
7/12/2025	8:30:00 AM	7/14/2025	12:30:34 PM	Carlyle Ave & Church Ave, Tyler, TX 75702	SS.GM.T0007472	Black Fork Creek	2400	1000	GRAVITY MAIN	BREAKS, OTHER CAUSES	No	Yes, 4/28/2020	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Sewer Main	Repair Sewer Main	No
7/23/2025	4:00:05 PM	7/23/2025	7:00:00 PM	2002 Bellwood Rd, Tyler, TX 75701	SS.GM.T0007197	Indian Creek	5400	2000	MANHOLE	VANDALISM	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Obstruction Removed from Main	No
7/24/2025	1:45:00 PM	7/24/2025	6:15:00 PM	722 E Locust St, Tyler, TX 75702	SS.GM.T0004852	Black Fork Creek	810	600	GRAVITY MAIN	CONTRACTOR DAMAGE	No	Yes, 7/23/2024	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
8/12/2025	12:00:00 PM	8/12/2025	5:00:00 PM	2518 McDonald Rd, Tyler, TX 75701	SS.MH.T0006738	Black Fork Creek	15,000	3000	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole/Invert	Repair Manhole/Invert	No
9/2/2025	12:00:00 PM	9/2/2025	4:00:00 PM	514 E 6th St, Tyler, TX 75701	SS.GM.T0006248	Black Fork Creek	1,200	500.00	GRAVITY MAIN	FATS, OIL, GREASE	No	YES, 3/2/2024	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
9/9/2025	12:00:00 PM	9/9/2025	4:00:00 PM	600 Turtle Creek Dr, Tyler, TX 75701	SS.GM.T0009718	Black Fork Creek	24,000	10000	GRAVITY MAIN	CONTRACTOR DAMAGE	No	Yes, 2/10/2020	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No
9/12/2025	9:09:00 AM	9/12/2025	11:39:00 PM	9106 C R 2120, Tyler, TX 75707	SS.FM.T0000056	Giley Creek	22,500	5000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes, 5/28/2017, 09/29/2020, & 10/7/2022	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Force Main	No
9/15/2025	10:00:47 AM	9/15/2025	11:00:50 AM	3332 W Northwest Loop 323, Tyler, TX 75702	SS.GM.T0007602	Contained in Yard	300	260	MANHOLE	FATS, OIL, GREASE	No	Yes, 12/5/2017, 07/13/2021, & 10/19/2022	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
9/18/2025	3:20:00 PM	9/18/2025	4:20:00 PM	2524 McDonald Rd, Tyler, TX 75701	SS.MH.T0006738	Black Fork Creek	1200	600	MANHOLE	BREAKS, OTHER CAUSES	No	Yes, 8/12/2025	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Manhole/Invert	Repair Manhole/Invert	No
9/12/2025	9:09:00 AM	9/12/2025	11:39:00 AM	9106 C R 2120, Tyler, TX 75707	SS.FM.T0000056	Giley Creek	22,500	5,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes, 5/28/2017, 09/29/2020, 10/7/2022 & 9/12/2025	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired Sewer Main	Repair Sewer Main	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.


Katherine Dietz, P.E. - Director of Utilities

10/17/2025
Date