


P. O. Box 2039
Tyler, Texas 75710



511 W. Locus
Tyler, Texas 75702

22 January 2026

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2025 Quarter 4 (October-December)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 October 2025 through 31 December 2025.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink that reads "Katherine Dietz".

Katherine Dietz, P.E.
Director of Utilities

Enclosures

**City of Tyler Consent Decree,
DOJ No. 90-5-1-09767
Quarterly Report - 2025 Quarter 4
01 October 2025 through 31 December 2025**

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Note
10/2/2025	11:00:00 AM	10/2/2025	3:00:00 PM	514 E 6th St. Tyler, TX 75701	SS.GM.T0006248	Black Fork Creek	1200	500	GRAVITY MAIN	FATS, OIL, GREASE	No	Yes. 3/2/24	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
10/13/2025	11:30:17 AM	10/13/2025	12:00:25 PM	600 Turtle Creek Dr. Tyler, TX 75701	SS.GM.T0009716	Black Fork Creek	750	300	GRAVITY MAIN	EQUIPMENT MALFUNCTION	No	Yes. 2/10/20 & 9/9/25	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Sewer Main	Replaced Bypass Plug	No
10/29/2025	8:30:00 AM	10/29/2025	9:20:00 AM	E 6th St & S Sneed Ave. Tyler, TX 75701	SS.GM.T0009024	Contained in Street	250	240	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
11/5/2025	7:00:00 PM	11/6/2025	7:30:56 PM	1283 C R 3180 Tyler, TX 75706	SS.GM.T0011771	Contained	300	270	PRIVATE CLEANOUT	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Sewer Main	Repair Sewer Main	No
11/17/2025	9:00:48 PM	11/17/2025	10:00:00 PM	3491 Professional Dr. Tyler, TX 75701	SS.GM.T0000958	Contained	180	180	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
12/5/2025	9:00:00 AM	12/5/2025	10:00:00 AM	220 Barbee Dr. Tyler, TX 75703	SS.GM.T0001505	West Mud Creek	1800	1000	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
12/7/2025	9:45:00 AM	12/8/2025	11:45:09 PM	Donnybrook Ave & Frazier St. Tyler, TX 75701	SS.GM.T0009217	Black Fork Creek	600	300	MANHOLE	DEBRIS	No	Yes. 8/19/19	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Schedule Manhole Repair	No
12/8/2025	9:00:00 AM	12/8/2025	12:00:00 PM	653 W Cumberland Rd. Tyler, TX 75703	SS.GM.T0011250	West Mud Creek	900	450	GRAVITY MAIN	BREAKS DUE TO EROSION	No	Yes. 8/30/23	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Sewer Main	Repair Sewer Main	No
12/10/2025	12:00:00 PM	12/16/2025	2:00:31 PM	9801 C R 274 Tyler, TX 75707	SS.FM.T0000057	Harris Creek	1200	600	FORCE MAIN	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Replaced Air Release Valve	Replaced Air Release Valve	No
12/11/2025	9:15:52 AM	12/11/2025	11:45:00 AM	County Road & Cecil Ave. Tyler, TX 75702	SS.GM.T0015057	Contained in Street	750	300	GRAVITY MAIN	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Removed Roots	Removed Roots	No
12/11/2025	9:00:00 AM	12/11/2025	12:00:00 PM	1818 Sentinel Way Tyler, TX 75703	SS.GM.T0014062	West Mud Creek	540	200	GRAVITY MAIN	BREAKS DUE TO EROSION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repaired Sewer Main	Repair Sewer Main	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

Katherine Dietz, P.E. Director of Utilities



1/22/26

Date