


P. O. Box 2039  
Tyler, Texas 75710



511 W. Locus  
Tyler, Texas 75701

24 April 2026

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087

Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-1-09767  
Quarterly Report – 2026 Quarter 1 (January – March)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 January 2026 through 31 March 2026.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

A handwritten signature in blue ink that reads "Kath. Dietz". The signature is written in a cursive, flowing style.

Katherine Dietz, P.E.  
Director of Utilities

Enclosures

City of Tyler Consent Decree,  
 DOJ No. 90-5-1-1-09767  
 Quarterly Report - 2026 Quarter 1  
 01 January 2026 through 31 March 2026

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notif. Made?
1/22/2026	10:30:00 AM	1/22/2026	11:00:20 AM	325 S Bos D Arc Ave, 75702	SS GM.T0008079	Contained	600	300	MANHOLE	VANDALISM	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Obstruction removed main	Yes
1/12/2026	3:30:17 PM	1/12/2026	4:30:22 PM	1800 Hickory Ln, 75703	SS GM.T0013369	Contained	300	250	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/14/2026	12:30:10 PM	1/14/2026	1:00:00 PM	1801 S Southwest Loop 323, TX, 75701	SS GM.T0000951	Contained	450	380	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/14/2026	9:00:00 AM	1/14/2026	2:00:00 PM	9125 Cherokee Trl, 75703	SS.MH.T0015086	Shackelford Creek	22,500	15,000	LIFT STATION	VANDALISM	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected	Stopped flushing by Contractor	No
1/30/2026	4:52:32 PM	1/30/2026	5:52:00 PM	Tanglewood Dr & S Southeast Loop 323	SS GM.T0005721	Contained	180	150	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
2/3/2026	12:45:16 PM	2/3/2026	1:45:33 PM	1009 Hudrall Dr, 75701	SS GM.T0003406	Contained	180	100	PRIVATE CLEANOUT	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Schedule follow-up CCTV inspection	No
2/20/2026	9:00:25 AM	2/20/2026	9:30:29 AM	858 S Southeast Loop 323, 75702	SS GM.T0013474	Contained	300	120	MANHOLE	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repair Manhole/Invert	Repair Manhole/Invert	No
2/23/2026	10:15:00 AM	2/23/2026	11:15:00 AM	858 S Southeast Loop 323, 75702 #2	SS GM.T0013474	Contained	600	200	MANHOLE	BREAKS, OTHER CAUSES	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repair Manhole/Invert	Repair Manhole/Invert	No
2/26/2026	10:33:00 AM	2/26/2026	11:45:00 AM	Garden Valley Rd & N Northwest Loop 323	SS GM.T0013190	Willow Creek	1440	700	GRAVITY MAIN	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list, Contact Pre-Treatment	No
3/2/2026	4:40:00 PM	3/2/2026	6:30:00 PM	4085 Hogan Dr, 75709	SS GM.T0011124	Contained	550	200	MANHOLE	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Remove Roots from Manhole	No
3/9/2026	12:15:28 PM	3/9/2026	1:15:36 PM	4821 Leisure Ln, 75703	SS GM.T0001053	Contained	600	275	MANHOLE	FATS, OIL, GREASE	No	Yes	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
3/17/2026	5:52:00 PM	3/17/2026	8:05:00 PM	10936 Spur 164, 75709	SS.FM.T0000042	Contained	2660	2660	FORCE MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Sewer Main Repaired	Repair Sewer Main	No
3/19/2026	10:15:59 AM	3/19/2026	11:15:12 AM	520 S Southwest Loop 323, 75702	SS GM.T0007243	Contained	600	400	MANHOLE	TUBERCULATION	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Heavy Clean & Place on High Frequency Cleaning list	No
3/23/2026	10:30:52 AM	3/23/2026	11:45:56 AM	3205 W Erwin St, 75702	SS GM.T0006556	Willow Creek	600	400	MANHOLE	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
3/23/2026	11:00:17 AM	3/23/2026	12:00:21 PM	Cambridge Cv & Harvard Dr	SS.MH.T0012800	Contained	90	90	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Repair Main	Repair Sewer Main	No
3/26/2026	2:00:27 PM	3/26/2026	2:45:31 PM	3973 Hanover Pl, 75701	SS GM.T0012848	Contained	90	80	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list, Contact Pre-Treatment	No
3/30/2026	6:30:00 PM	3/30/2026	7:30:00 PM	4030 Silverwood Dr, 75701	SS GM.T0000637	West Maid Creek	600	400	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Contact Pre-Treatment	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kathrine Dent, P.E., Director of Utilities



4-27-26  
Date