



HOGAN LIFT STATION



Tyler, Texas
Hogan Lift Station



- Cleanout
- ▲ EOM
- Manhole
- Mainline
- ◆ ARV
- Pump Station
- - - Force Main

F

Tyler Water Utilities - Lift Station Assessment Form

Lift Station Name HOGAN Type Submersible
 Location/Address 3984 Hogan Dr.
 Lift Station Asset ID _____ Number of Pumps 2
 Firm Capacity in GPM (all pumps operating) _____
 Firm Capacity in GPM (largest pump out of service) _____
 Inspector Don White Date Dec 12, 2017
 City Works Work Order _____

Building and Grounds

Good Fair Poor Critical N/A

Building Structure	Type: <u>NONE</u>					
Building Roof/Ceiling		☐	☐	☐	☐	☐
Building Finishes		☐	☐	☐	☐	☐
Building Doors and Windows		☐	☐	☐	☐	☐
Building HVAC	Type: _____	☐	☐	☐	☐	☐
Fencing	<u>25 X 32</u> Type: <u>Chain Link</u>	☒	☐	☐	☐	☐
<u>4' ped</u> Gates	<u>13' Vehicular</u> Type: <u>11</u>	☐	☒	☐	☐	☐
Site/Grounds	Size: <u>25 X 32</u>	☐	☐	☐	☐	☐
Lighting	☒	☒	☐	☐	☐	☐
Pavement (Driving)	Type: <u>CONCRETE</u>	☒	☐	☐	☐	☐
Drainage	Type: <u>SURFACE</u>	☐	☒	☐	☐	☐
Odor	Comment: <u>NONE</u>	☒	☐	☐	☐	☐
Odor Control System	Type: _____	☐	☐	☐	☐	☐
Odor Control Mechanical		☐	☐	☐	☐	☐
Odor Control Media	Type: _____	☐	☐	☐	☐	☐
Noise		☒	☐	☐	☐	☐
Overall Site Appearance		☒	☐	☐	☐	☐

Comments Some erosion undermining slab perimeter.
Vehicular gate does not close properly

Structural

		Good	Fair	Poor	Critical	N/A
Wet Well						
Debris	Size:	☐	☒	☐	☐	☐
Fats, oils, and grease		☐	☐	☒	☐	☐
Ventilation		☒	☐	☐	☐	☐
Walls	Material: <u>Pipe Concrete</u>	☐	☒	☐	☐	☐
Coatings	Type: <u>?</u>	☐	☐	☐	☐	☐
Access Hatches	Number: <u>3 x 5 Double</u>	☒	☐	☐	☐	☐
<u>combination Slab wetwell & valve pit 18x26 Conc rete</u>		☒	☐	☐	☐	☐
Dry Well/Valve Vault						
Walls <u>4'-6" x 4'-6"</u>	Material: <u>Concrete</u>	☒	☐	☐	☐	☐
Coatings	Type: <u>?</u>	☐	☐	☐	☐	☐
Grating/Hatching	Number: <u>METAL 3x3</u>	☒	☐	☐	☐	☐
Stairway/Ladder	Material: <u>---</u>	☐	☐	☐	☐	☐
<u>Sump</u> Pump	Number: <u>Floor Drain</u>	☒	☐	☐	☐	☐
Ventilation	Type: <u>Pipe</u>	☒	☐	☐	☐	☐
Comments <u>Wetwell aggregate exposed at and below high water line. Air compressor for aeration of wetwell</u>						

Mechanical

		Good	Fair	Poor	Critical	N/A
Bypass Connection	(Circle) YES / NO					
Piping and Valves						
Suction Valve	Number:	☐	☐	☐	☐	☐
<u>4" DI</u> Check Valve	Number: <u>2</u>	☐	☐	☒	☐	☐
<u>4" DI</u> Discharge Valve	Number: <u>3</u>	☐	☒	☐	☐	☐
Mechanical (continued) <u>ONE DISCHARGE VALVE BETWEEN two discharge lines.</u>						
Riser Piping	Material: <u>DI</u>	☐	☐	☒	☐	☐
<u>CORROSION</u>						

4"	Discharge Piping	Material:	DE	☒	☐	☐	☐	☐
4"	Fittings	Material:	DI	☐	☐	☒	☐	☐

Comments _____

Pumps							
Pump 1	Asset ID	Make	Model				
	Capacity	GPM					
	Impeller Dia./Code	Horsepower					
			Good	Fair	Poor	Critical	N/A
	Pump		☐	☐	☐	☐	☐
	Seals		☐	☐	☐	☐	☐
	Motor		☐	☐	☐	☐	☐
	Shaft		☐	☐	☐	☐	☐
	Electrical Cable						
	Noise		☒	☐	☐	☐	☐
	Vibration/Heat		☐	☐	☐	☐	☐
Pump 1	The following components are to be inspected during pump disassembly						
	Oil		☐	☐	☐	☐	☐
	Impeller		☐	☐	☐	☐	☐
	Packing Rings		☐	☐	☐	☐	☐
	Internal Seals		☐	☐	☐	☐	☐

1 new chain
 1 chain good condition
 elect cable good

Pump 2

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 2*The following components are to be inspected during pump disassembly*

Oil

Impeller

Packing Rings

Internal Seals

Pump 3

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 3*The following components are to be inspected during pump disassembly*

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 4

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable	☐	☐	☐	☐	☐
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 4*The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 5

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 5*The following components are to be inspected during pump disassembly*

Oil

Impeller

Packing Rings

Internal Seals

Pump 6

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 6*The following components are to be inspected during pump disassembly*

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Electrical System

	Good	Fair	Poor	Critical	N/A
Electrical System Power		Volt/Phase:			
Panel/Enclosures	NEMA4X	YES	NO	☒	☐
Transformers (AEP)		☐	☐	☐	☐
Disconnect	Type:	☐	☐	☐	☐
Generator	KW	Yes	☒	☐	☐
Transfer Switch		Yes	☒	☐	☐
Electrical System Control					
Breakers	Type:	☐	☐	☐	☐
Speed control/VFD	Type:	☐	☐	☐	☐
Starters	Type:	☐	☐	☐	☐
Control Relays	Type:	☐	☐	☐	☐

Comments

Instrumentation/SCADA

				Good	Fair	Poor	Critical	N/A
Panel	NEMA4X	YES	NO	☐	☐	☐	☐	☐
Instrumentation								
Level	Type:	<u>ultra sonic</u>		☒	☐	☐	☐	☐
Flow	Type:	<u>No</u>		☐	☐	☐	☐	☐
Instrumentation/SCADA (continued)				Good	Fair	Poor	Critical	N/A
PLC	Type:			☐	☐	☐	☐	☐
SCADA				☐	☐	☐	☐	☐
RTU	Type:	<u>uplink</u>		☒	☐	☐	☐	☐
Radio/ <u>Antenna</u>	Type:	<u>on uplink</u>		☒	☐	☐	☐	☐
Comments	<u>Visual Alarm</u>							

Building and Grounds



Lift Station Perimeter Facing West



Erosion Near West Fence

Structural



Valve Vault



Check Valve in Valve Vault With Some Corrosion

Mechanical




Bolts on Check Valve Showing Some Corrosion



Riser Pipe in Wet Well- Corroded

Electrical



Front of Generator



Inside Generator (1)



Inside Generator (2)



Inside Generator (3)


Instrumentation/SCADA




Front Instrumentation Panel



Inside of Instrumentation Panel (1)



Inside of Instrumentation Panel (2)





Inside of Instrumentation Panel Door

Instrumentation/SCADA





Uplink RTU Inside Instrumentation Panel



NOTE:
LIFT STATION TO BE A DUPLEX STATION WITH 4" DISCHARGE AND VALVING;
STAINLESS STEEL (316LSS) LIFTING CABLE WITH SAFETY HOOK AND GRIP EYE;
STAINLESS STEEL GUIDE RAILS; SS GUIDE BAR BRACKET AND CABLE HOLDER;
LEVEL CONTROL SWITCHES; FLYGT CONTROL PANEL; DUPLEX IN NEMA 4X SS
ENCLOSURE WITH 1/2" MIN. THICK GLASS TRANSPARENT WINDOW;
HIGH LEVEL AND LOW LEVEL ALARMS; DUPLEX ALTERNATOR; DIM GLOW
LIGHTED GROUND FALT RECEPTACLE; MINI-CAS UNITS, PUMP ALARM PILOT
LIGHT, RUN PILOT LIGHTS, SOW HEATER WITH THERMOSTAT, PHASE MONITOR,
SURGE ARRESTOR, REMOTE ALARM TERMINAL BLOCK, NEMA 4 HOA SWITCHES,
ELECTRIC REVERSE TRANSDUCER, TRANSFORMER;
LIGHTNING ARRESTOR AND UL LISTING FOR THE COMPLETE PANEL. ACCESS
COVERS TO BE 3" HEAVY DUTY ALUMINUM, SINGLE LEAF, 36"x48" MODEL
FILE-8 RATED FOR 300 LBS PER SF; PEDESTRIAN RATED, INCLUDE 1/2 HP AIR
COMPRESSOR WITH SCH 40 PIPING FOR AERATION OF WELL WATER. AUTOMATE
AIR START 30 MIN AFTER PUMPS STOP. AUTO DIALER TO BE CITY OF
TYLER. CONTACT EARL BROWN (903) 595-1678.

ADDITIONAL NOTES:

1. PUMPS SHALL BE 3 PHASE
2. BRACKET FOR AIR LINE SHALL BE STAINLESS STEEL
3. MINIMUM 16--FEET WIDE GATE ON FENCE
4. FENCE SHALL BE MAN PROOF PREFERABLY CHAIN LINK
5. DUAL GUIDE RAILS FOR PUMPS
6. SCREEN ON VENT PIPES TO BE STAINLESS STEEL
7. PVC PIPE SERVING AIR LINE SHALL HAVE A RUBBER TIE JACKET WHERE ENTERING AND THROUGH CONCRETE WALL
8. AIR COMPRESSOR SHALL BE RATED FOR CONTINUOUS DUTY
9. FIVE COPIES OF OIL PUMP MANUALS ARE REQUIRED
10. AS--BUILT DRAWINGS REQUIRED FOR WET WELL AND ELECTRICAL PANEL
11. GENERATOR WITH 4 HOUR MINIMUM CAPACITY SHALL BE INSTALLED TO OPERATE THE LIFT STATION IN THE EVENT OF A POWER OUTAGE
12. TWO PUMPS SHALL OPERATE SIMULTANEOUSLY, SHALL NOT EXCEED 180 GPM PEAK DISCHARGE



RECORD DRAWINGS

THESE RECORD DOCUMENTS HAVE BEEN PREPARED
BASED ON INFORMATION PROVIDED FROM CONATSER
CONSTRUCTION TX, L.P. RKM CONSULTING ENGINEERS,
INC. HAS NOT VERIFIED THE ACCURACY AND/OR
COMPLETENESS OF THIS INFORMATION. RKM CONSULTING
ENGINEERS, INC. SHALL NOT BE RESPONSIBLE FOR ANY
ERRORS OR OMISSIONS THAT MAY BE INCORPORATED AS A
RESULT OF ERRONEOUS INFORMATION PROVIDED BY
OTHERS.

REV.	DATE	REMARKS					
LIFT STATION DETAILS CASCADES UNIT VI CITY OF TYLER, TEXAS							
		RKM Consulting Engineers, Inc. 7616 LBJ Freeway, Suite 530 Dallas, Texas 75251 Copyright © 2008 RKM Consulting Engineers, Inc.				phone (214) 432-8800 fax (214) 432-8800	
CHECKED	DESIGN	DRAWN	JOB	DATE	SCALE	SHEET	
RKM	RKM	RKM	1026-001	03/19/07	NONE	39 OF	

Project
Customer pos.no
Project ID
Pos.no
Created by

City of Tyler
3", 25HP, 74.5% Eff., 7 Year Warranty
1
PSI - Brett Rose



Page 1 / 5
2016-11-28

Data sheet

Pump type

KRT E 80-251/194XG-S

Operating data

Flow	516	US g.p.m.	Fluid		
Head	95.9	ft	Density	62.3	lb/ft ³
Operating speed	1750	rpm	Viscosity	1.08E-5	ft ² /s
Shaft power	16.8	hp	Temperature	68	°F
Efficiency	74.5	%			
Required pump NPSH	14	ft			
Head H(Q=0)	135	ft			
Application range	Head		Flow		
	From	117	ft	151	US g.p.m.
	To	60	ft	1050	US g.p.m.

Design

Make	KSB	Impeller type	Single vane impeller
Design	Submersible pump		Closed
Series	KRT E	Impeller size	(270) 10 ⁵ / ₈ inch
Frame size	80-251		Max. (270) 10 ⁵ / ₈ inch
Stages	1		Min. (210) 8 ¹ / ₄ inch
Curve number	K42592/4	Free passage	3 inch
		Weight	512.57 lb
Type of bearings	Antifriction		
Nos. of bearings	1 / 1		
Lubrication	Grease lubrication, lubricated for lifetime		
Suction port	Pressure rating	---	
	Nominal pipe size DN0	---	
	Nominal pipe size DN1	4"	
	Norm	---	
Discharge port	Pressure rating	CLASS 125	
	Nominal pipe size DN2	3 inch	
	Nominal pipe size DN3	3 inch	
	Norm	ASME/ANSI B16.1	
Suction port: pump (DN1)		Discharge port: discharge elbow (DN3)	

Materials

Pump casing	Grey cast iron EN-GJL-250 (A 48 Class 35B)
Discharge cover	Grey cast iron EN-GJL-250 (A 48 Class 35B)
Impeller	Grey cast iron EN-GJL-250 (A 48 Class 35B)
Shaft	Stainless steel EN-1.4021+QT800 (A 276 Type 420)
Bearing bracket	Grey cast iron EN-GJL-250 (A 48 Class 35B)
Motor casing	Grey cast iron EN-GJL-250 (A 48 Class 35B)
Bolts, nuts	Stainless steel A4 (EN-1.4571) (A 276 Type 316)
Shaft protection sleeve	---
Casing wear ring	Grey cast iron EN-JL 1030 (A 48 Class 30B)
Impeller wear ring	---
O-Rings	Nitrile rubber (NBR)

KSB Inc., 4415 Sarellen Road, Richmond, Virginia 23231, Phone: 001-804-222-1818, Fax: 001-804-226-6961

KSB Pumps Inc, 5885 Kennedy Road, Mississauga, Ontario L4Z 2G3 (Canada), Phone: (0905) 568-9200, Fax: (0905) 568-9120

KSB Aktiengesellschaft, Turmstrasse 92, 06110 Halle (Germany), Phone +49 (345) 48260, Fax +49 (345) 4826 4699, www.ksb.com


Project City of Tyler
 Customer pos.no
 Project ID 3", 25HP, 74.5% Eff., 7 Year Warranty
 Pos.no 1
 Created by PSI - Brett Rose



Page 3 / 5
 2016-11-28






Performance curve

Pump type **KRT E 80-251/194XG-S**



Impeller type	Single vane impeller	Curve number	K42592/4
Free passage	3"	Density	62.322 lb/ft³
Impeller size	10 5/8" (270)	Viscosity	1.082E-5 ft²/s
		Speed	1750 1/min

KSB Inc., Richmond, VA. / KSB Pumps Inc., Mississauga, Ontario / KSB AG, Halle (Germany)




UNUR FÜR ANFRAGE/ANGEBOT
technische Änderungen vorbehalten
FOR INQUIRY/OFFER ONLY
technical modifications reserved
SEULEMENT POUR LES DEMANDES/LES OFFRES
sous réserve de modifications technique

Hydraulik Hydraulics Hydraulique	KSB-Motor KSB-Engine KSB-Moteur	a1		Gewicht / Weight / Poids	
		mm	inch	Material version/variant G	
				kg	lbs
E	74	596	23 8/16	152	335
	114	626	24 5/8	166	365
	194	626	24 5/8	177	390
	46	596	23 8/16	138	305
	66	596	23 8/16	150	330
	96	626	24 5/8	161	355
	126	626	24 5/8	175	395


Zürcherge-Str. / Drawing No. / Pflanz	2005-08-04	Paula	1	Berliner-Str. / Customer No. / Klient
Mo. gita / Seite / Etage	2005-05-24	Paula	0	KSB Auftrags-Nr. / KSB Order No. / Commande KSB
1:10 A3	Datum / Date	Name / Nom	Reinigung / Nettoyage	
	Blaukreide-Dia / Crayon-Size			KSB Werk-Nr. / KSB Work No. / Nr. de Manufacture KSB
	KRT E 80-251			
	stationäre Aufstellung stationary installation Installation stationnaire			
	Bitte geschäftlich bei Schlichtermeister / S'adresser chez le spécialiste / A l'adresse des seuls correspondants			
	KSB Mehrsprachigkeit multilingualism / polylinguisme	Postfach 20 07 43 D-55008 Itzer (Sonn) Telefon 0492-1300 Telefax 0492-1301	Tel.: (03 45) 48 26-0 Fax: (03 45) 48 26 48	

1) Minimum water level
1) Niveau d'eau minimum

NOTTINGHAM LANE LIFT STATION



Tyler, Texas
Nottingham Lift Station



- Cleanout
- ▲ EOM
- Manhole
- Mainline
- ◆ ARV
- Pump Station
- - - Force Main

Tyler Water Utilities - Lift Station Assessment Form

Lift Station Name NOTTINGHAM Type Submersible
 Location/Address 9799 County Road 274
 Lift Station Asset ID _____ Number of Pumps 2
 Firm Capacity in GPM (all pumps operating) _____
 Firm Capacity in GPM (largest pump out of service) _____
 Inspector Don White Date Dec 13, 2017
 City Works Work Order _____

Building and Grounds

Good Fair Poor Critical N/A

Building Structure	Type: <u>NONE</u>					
Building Roof/Ceiling		☐	☐	☐	☐	☐
Building Finishes		☐	☐	☐	☐	☐
Building Doors and Windows		☐	☐	☐	☐	☐
Building HVAC	Type: _____	☐	☐	☐	☐	☐
Fencing	Type: <u>Chain Link</u>	☒	☐	☐	☐	☐
Gates <u>Double 20'</u>	Type: <u>11</u>	☒	☐	☐	☐	☐
Site/Grounds <u>Variable length/width</u>	Size: <u>+/- 83' x 41'</u>	☒	☐	☐	☐	☐
Lighting <u>BROKEN</u>		☐	☐	☐	☒	☐
Pavement (Driving)	Type: <u>GRAVEL</u>	☐	☐	☒	☐	☐
Drainage	Type: <u>Surface</u>	☐	☐	☒	☐	☐
Odor	Comment: <u>NONE</u>	☒	☐	☐	☐	☐
Odor Control System	Type: _____	☐	☐	☐	☐	☐
Odor Control Mechanical		☐	☐	☐	☐	☐
Odor Control Media	Type: _____	☐	☐	☐	☐	☐
Noise		☐	☐	☐	☐	☐
Overall Site Appearance		☐	☒	☐	☐	☐

Comments GENERATOR SLAB FLUSH WITH NATURAL GROUND allows
Surface drainage to contact + Generator Base support.
Driveway has cement bags to fill sump at Road. Erosion
along Fence line Exposed Fence pole piers.
Erosion From high water in adjacent creek could undermine
wet well.

Structural

			Good	Fair	Poor	Critical	N/A
Wet Well	concrete	Size: 8' ϕ					
Debris			☐	☒	☐	☐	☐
Fats, oils, and grease			☐	☐	☒	☐	☐
Ventilation	Pipe		☒	☐	☐	☐	☐
Walls	Material: CONCRETE		☒	☐	☐	☐	☐
Coatings	✓ Type:		☐	☒	☐	☐	☐
Access Hatches	Number: 1 Double metal 6' x 4'		☒	☐	☐	☐	☐
Slab	Conc. 9'-6" ϕ		☒	☐	☐	☐	☐
Dry Well/Valve Vault	4' ϕ						
Walls	Material: Conc		☒	☐	☐	☐	☐
Coatings	Type: None		☐	☐	☐	☐	☒
Grating/Hatching	Number: 1 Metal 3' x 3'		☒	☐	☐	☐	☐
Stairway/Ladder	Material: None		☐	☐	☐	☐	☒
Sump/Pump	Number: Standing water on floor		☐	☐	☒	☐	☐
Ventilation	Type: Pipe		☒	☐	☐	☐	☐

Comments Oil, grease, sludge cover fluid surface in wetwell, sludge debris at top of wetwell indicates previous overflow potential

Mechanical

			Good	Fair	Poor	Critical	N/A
Bypass Connection	(Circle) YES / NO						
Piping and Valves							
Suction Valve	Number:		☐	☐	☐	☐	☐
DI Check Valve	Number: 2		☐	☐	☒	☐	☐
DI Discharge Valve	Number: 2		☐	☐	☒	☐	☐

Mechanical (continued)

			Good	Fair	Poor	Critical	N/A
Riser Piping	Material: DI		☐	☐	☒	☐	☐

Combined
Not Visible

Discharge Piping

Material:

DI

☐ ☐ ☒ ☐ ☐

Fittings

Material:

DI

☐ ☐ ☒ ☐ ☐

Comments In individual discharge pipe thru valves with
CORROSION

Pumps

Pump 1

Asset ID

Make

Model

Capacity

GPM

Impeller Dia./Code

Horsepower

Good Fair Poor Critical N/A

Pump

☐ ☐ ☐ ☐ ☐

Seals

☐ ☐ ☐ ☐ ☐

Motor

☐ ☐ ☐ ☐ ☐

Shaft

☐ ☐ ☐ ☐ ☐

Electrical Cable

Noise

☐ ☐ ☐ ☐ ☐

Vibration/Heat

☒ ☐ ☐ ☐ ☐

Pump 1

The following components are to be inspected during pump disassembly

Oil

☐ ☐ ☐ ☐ ☐

Impeller

☐ ☐ ☐ ☐ ☐

Packing Rings

☐ ☐ ☐ ☐ ☐

Internal Seals

☐ ☐ ☐ ☐ ☐

Pump 1 & 2 Electric Cable, Guide Rails, Chain - Good

Pump 2

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 2*The following components are to be inspected during pump disassembly*

Oil

Impeller

Packing Rings

Internal Seals

Pump 3

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 3*The following components are to be inspected during pump disassembly*

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 4

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 4*The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 5

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 5*The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 6

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable	☐	☐	☐	☐	☐
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 6

The following components are to be inspected during pump disassembly

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Electrical System

	Good	Fair	Poor	Critical	N/A
Electrical System Power					
Volt/Phase:					
Panel/Enclosures	NEMA4X	YES	NO	☐	☐
Transformers (AEP)		☐	☐	☐	☐
Disconnect	Type:	☐	☐	☐	☐
Generator	KW	YES	☒	☐	☐
Transfer Switch	YES	☒	☐	☐	☐
Electrical System Control					
Breakers	Type:	☐	☐	☐	☐
Speed control/VFD	Type:	☐	☐	☐	☐
Starters	Type:	☐	☐	☐	☐
Control Relays	Type:	☐	☐	☐	☐

Comments Visual and Sound ALARM

Instrumentation/SCADA

			Good	Fair	Poor	Critical	N/A
Panel	NEMA4X	<u>YES</u>	NO	☒	☐	☐	☐

Instrumentation

Level	Type:	<u>Floats</u>	☐	☒	☐	☐	☐
Flow	Type:	<u>N/A</u>	☐	☐	☐	☐	☒

Instrumentation/SCADA (continued)

			Good	Fair	Poor	Critical	N/A
PLC	Type:		☐	☐	☐	☐	☐
SCADA			☐	☐	☐	☐	☐
RTU	Type:	<u>Uplink</u>	☒	☐	☐	☐	☐
Radio/Antenna	Type:	<u>Small attached to uplink</u>	☒	☐	☐	☐	☐

Comments Level Floats have sludge attached

Building and Grounds



Lift Station Perimeter Facing West



Generator Slab Flush With Ground, Allows Water to Come into Contact With Generator Base



Erosion Exposing Fence Pole Piers



Flooding from Adjacent Creek Could Cause I/I Into Wet Well In Future

Building and Grounds



Exterior of Wet Well With Hatch Open and Vent Pipe for Wet Well



Exterior of Valve Vault and Vent Pipe

Structural




Fat, Oil and Grease Deposits on Wet Well



Debris at Top of Wet Well Indicate Previous Overflow Conditions

Mechanical




Check Valves in Poor Condition. Drain in Valve Vault Not Functioning Properly
Leading to Water Accumulation

Electrical



Front of Generator



Inside Generator (1)



Inside Generator (2)



Inside Generator (3)


Instrumentation/SCADA



Front Instrumentation Panel



Inside of Instrumentation Panel (1)



Inside of Instrumentation Panel (2)




Inside of Instrumentation Panel Door

Instrumentation/SCADA





Instrumentation Panel Facing South



EXPLOSION PROOF VERSION

				PERFORMANCE CURVE				PRODUCT NP3171.091		TYPE SH	
DATE 2008-11-03		PROJECT Nottingham L.S. - Present						CURVE NO 63-275-00-1070		ISSUE 1	
POWER FACTOR EFFICIENCY MOTOR DATA		1/1-LOAD 0.92 90.5 %	3/4-LOAD 0.91 91.5 %	1/2-LOAD 0.86 92.0 %	RATED POWER 35 hp		IMPELLER DIAMETER 195 mm				
					STARTING CURRENT ... 273 A						
COMMENTS NEMA Code Letter: A					RATED CURRENT ... 39 A		MOTOR # 25-18-2AA		STATOR 1 D		REV 10
					RATED SPEED 3520 rpm		FREQ. 60 Hz	PHASES 3	VOLTAGE 460 V	POLES 2	
			INLET/OUTLET - / 4 inch		TOT.MOM.OF INERTIA ... 0.073 kgm2		GEARTYPE ---		RATIO ---		
			IMP. THROUGHLET ---		NO. OF BLADES 2						




NPSHre = NPSH3% + min. operational margin
Performance with clear water and ambient temp 40 °C



CURVE

PILOT TRUCK LIFT STATION



Tyler Water Utilities - Lift Station Assessment Form

Lift Station Name PILOT Type Submersible
 Location/Address 12292 FM 14
 Lift Station Asset ID _____ Number of Pumps 2
 Firm Capacity in GPM (all pumps operating) _____
 Firm Capacity in GPM (largest pump out of service) _____
 Inspector Don White Date Dec 18, 2017
 City Works Work Order _____

Building and Grounds

Good Fair Poor Critical N/A

Building Structure	Type: <u>NONE</u>					
Building Roof/Ceiling		☐	☐	☐	☐	☐
Building Finishes		☐	☐	☐	☐	☐
Building Doors and Windows		☐	☐	☐	☐	☐
Building HVAC	Type: <u>Chain Link</u>	☐	☐	☐	☐	☐
Fencing	Type: <u>Chain Link</u>	☒	☐	☐	☐	☐
Gates <u>DOUBLE 15'-6"</u>	Type: <u>11</u>	☒	☐	☐	☐	☐
Site/Grounds	Size: <u>57'W X 122'D</u>	☒	☐	☐	☐	☐
Lighting		☒	☐	☐	☐	☐
Pavement (Driving)	Type: <u>CONCRETE</u>	☒	☐	☐	☐	☐
Drainage <u>Surface</u>	Type: <u>SURFACE</u>	☒	☐	☐	☐	☐
Odor	Comment: _____	☐	☒	☐	☐	☐
Odor Control System	Type: _____	☐	☐	☐	☐	☐
Odor Control Mechanical		☐	☐	☐	☐	☐
Odor Control Media	Type: _____	☐	☐	☐	☐	☐
Noise		☐	☐	☐	☐	☐
Overall Site Appearance		☒	☐	☐	☐	☐

Comments _____

Structural

Good Fair Poor Critical N/A

Wet Well		Size: 6' ϕ				
Debris			☒	☐	☐	☐
Fats, oils, and grease			☒	☐	☐	☐
Ventilation Pipe			☐	☒	☐	☐
Walls	Material: Concrete		☐	☒	☐	☐
Coatings	Type:		☐	☒	☐	☐
Access Hatches	1 Number: METAL DOUBLE 4'-6" x 2'-6"		☐	☒	☐	☐
Slab	CONCRETE		☒	☐	☐	☐
Dry Well/Valve Vault		4' ϕ 6' Deep slab 5' ϕ				
Walls	Material: Concrete		☒	☐	☐	☐
Coatings	Type:		☒	☐	☐	☐
Grating/Hatching	1 Number: METAL 3' x 3'		☐	☒	☐	☐
Stairway/Ladder	Material:		☐	☐	☐	☐
Sump/Pump	Number: PVC PIPE TO WET WELL		☒	☐	☐	☐
Ventilation	Type: PIPE		☐	☐	☒	☐

Wet well hatch propped open with 4x4 wood
 Comments Guide Rails - Fair, Lift chains - Good, electric

conduits - Good. Some aggregate exposed on lower level
 of wet well wall. 3/4" compressed air line to wet
 well for aeration. Combined wet well/valve vault
 slab 30x25'

Mechanical

Good Fair Poor Critical N/A

Bypass Connection	(Circle) YES 1 NO					
Piping and Valves						
Suction Valve	Number: —		☐	☐	☐	☐
Check Valve	Number: 2-6" DI		☐	☐	☒	☐
Discharge Valve	Number: 2-6" DI		☐	☐	☒	☐

Mechanical (continued)

Good Fair Poor Critical N/A

Riser Piping	Material: 6" DI		☐	☐	☒	☐
--------------	-----------------	--	-----------------------	-----------------------	----------------------------------	-----------------------

Discharge Piping	Material:	<u>6" DI</u>	☐	☐	☒	☐	☐
Fittings	Material:	<u>6" DI</u>	☐	☐	☒	☐	☐

Comments Significant corrosion on all elements.
Combination of discharge piping to one pipe not
visible. compressor for aeration of wet well.

Pumps							
Pump 1	Asset ID	Make	Model				
	Capacity	GPM					
	Impeller Dia./Code	Horsepower					
			Good	Fair	Poor	Critical	N/A
Pump			☐	☐	☐	☐	☐
Seals			☐	☐	☐	☐	☐
Motor			☐	☐	☐	☐	☐
Shaft			☐	☐	☐	☐	☐
Electrical Cable							
Noise			☐	☐	☐	☐	☐
Vibration/Heat			☐	☐	☐	☐	☐
Pump 1	The following components are to be inspected during pump disassembly						
Oil			☐	☐	☐	☐	☐
Impeller			☐	☐	☐	☐	☐
Packing Rings			☐	☐	☐	☐	☐
Internal Seals			☐	☐	☐	☐	☐

Pump 2 Asset ID _____ Make _____ Model _____

Capacity _____ GPM _____

Impeller Dia./Code _____ Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 2 *The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 3 Asset ID _____ Make _____ Model _____

Capacity _____ GPM _____

Impeller Dia./Code _____ Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 3*The following components are to be inspected during pump disassembly*

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 4

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 4*The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 5

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 5*The following components are to be inspected during pump disassembly*

Oil

Impeller

Packing Rings

Internal Seals

Pump 6

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 6

The following components are to be inspected during pump disassembly

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Electrical System

	Good	Fair	Poor	Critical	N/A
Electrical System Power					
Volt/Phase:					
Panel/Enclosures	NEMA4X	YES	NO	☒	☐
Transformers (AEP)		☐	☐	☐	☐
Disconnect	Type:	☐	☐	☐	☐
Generator	KW	YES	☒	☐	☐
Transfer Switch		✓	☒	☐	☐
Electrical System Control					
Breakers	Type:	☐	☐	☐	☐
Speed control/VFD	Type:	☐	☐	☐	☐
Starters	Type:	☐	☐	☐	☐
Control Relays	Type:	☐	☐	☐	☐

Comments Visual and sound alarm. some corrosion on transfer switch box

Instrumentation/SCADA

				Good	Fair	Poor	Critical	N/A
Panel	NEMA4X	YES	NO	☐	☐	☐	☐	☐

Instrumentation

Level	Type: <u>ultrasonic</u>	☒	☐	☐	☐	☐
Flow	Type: <u>No</u>	☐	☐	☐	☐	☐

Instrumentation/SCADA (continued)

Instrumentation/SCADA (continued)			Good	Fair	Poor	Critical	N/A
PLC	Type:		☐	☐	☐	☐	☐
SCADA			☐	☐	☐	☐	☐
RTU	Type:	UPLINK	☒	☐	☐	☐	☐
Radio/ <u>Antenna</u>	Type:	on LIGHT POLE	☒	☐	☐	☐	☐

Comments electric Junction box at wet well hatch
propped open with piece of wood

Building and Grounds



Lift Station Perimeter Facing East



Lift Station Grounds Facing Southeast

Structural



Electric Junction Box Near Wet Well



Wet Well in Good Condition

Mechanical



Suction Pipe Shows Signs of Corrosion



Ventilation Pipe Shows Significant Corrosion




Check Valves With Significant Corrosion

Electrical



Front of Generator



Inside Generator (1)




Inside Generator (2)



Inside Generator (3)

Electrical



Interior of Electrical Junction Box Observed Near Wet Well.


Instrumentation/SCADA



Front Instrumentation Panel



Inside of Instrumentation Panel (1)



Inside of Instrumentation Panel (2)



Inside of Instrumentation Panel Door

Instrumentation/SCADA



Uplink RTU in Good Condition




Instrumentation Panel in Good Condition




NP 3153 SH 3~ 276 — *Pilot Truck Lift Station*

Technical specification



Installation: P - Semi permanent, Wet



Note: Picture might not correspond to the current configuration.

General

Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Possible to be upgraded with Guide-pin® for even better clogging resistance. Modular based design with high adaptation grade.

Impeller

Impeller material	Grey cast iron
Discharge Flange Diameter	3 1/8 inch
Suction Flange Diameter	150 mm
Impeller diameter	158 mm
Number of blades	2


Motor

Motor #	N3153.181 21-18-2FB-W 17hp
Stator variant	4
Frequency	60 Hz
Rated voltage	460 V
Number of poles	2
Phases	3~
Rated power	17 hp
Rated current	19 A
Starting current	150 A
Rated speed	3510 rpm
Power factor	
1/1 Load	0.93
3/4 Load	0.91
1/2 Load	0.86
Pump Efficiency	
1/1 Load	91.5 %
3/4 Load	92.0 %
1/2 Load	92.5 %

Configuration

Project	Project ID	Created by	Created on	Last update
			2017-04-17	


NP 3153 SH 3~ 276 Duty Analysis



Pumps running /System	Individual pump			Total					
	Flow	Head	Shaft power	Flow	Head	Shaft power	Pump eff.	Specific energy	NPSH _{re}
1	321 US g.p.m.	97.9 ft	14.6 hp	321 US g.p.m.	97.9 ft	14.6 hp	54.4 %	615 kWh/US MG	13.9 ft

Project	Project ID	Created by	Created on	Last update
			2017-04-17	


NP 3153 SH 3~ 276 VFD Analysis



Pumps running /System	Frequency	Flow	Head	Shaft power	Flow	Head	Shaft power	Hyd eff.	Specific energy	NPSHre
1	60 Hz	321 US g.p.m.	97.9 ft	14.6 hp	321 US g.p.m.	97.9 ft	14.6 hp	54.4 %	615 kWh/US MG	13.9 ft
1	54.7 Hz	277 US g.p.m.	83.9 ft	11 hp	277 US g.p.m.	83.9 ft	11 hp	53.4 %	534 kWh/US MG	11.9 ft
1	49.8 Hz	233 US g.p.m.	72 ft	8.2 hp	233 US g.p.m.	72 ft	8.2 hp	51.8 %	473 kWh/US MG	10.1 ft
1	44.8 Hz	186 US g.p.m.	61.5 ft	5.9 hp	186 US g.p.m.	61.5 ft	5.9 hp	49 %	431 kWh/US MG	8.4 ft
1	39.8 Hz	134 US g.p.m.	52.5 ft	4.06 hp	134 US g.p.m.	52.5 ft	4.06 hp	43.7 %	422 kWh/US MG	6.92 ft


Project	Project ID	Created by	Created on	Last update
			2017-04-17	

NP 3153 SH 3~ 276 Dimensional drawing




Project	Project ID	Created by	Created on	Last update
			2017-04-17	

RUSTIC PARK LIFT STATION



Tyler, Texas
Rustic Lift Station



- Cleanout
- ▲ EOM
- Manhole
- Mainline
- ◆ ARV
- ⊠ Pump Station
- - - Force Main

Tyler Water Utilities - Lift Station Assessment Form

Lift Station Name RUSTIC Type SELF Priming
 Location/Address 3284 N. Northeast Loop 323
 Lift Station Asset ID _____ Number of Pumps 2
 Firm Capacity in GPM (all pumps operating) _____
 Firm Capacity in GPM (largest pump out of service) _____
 Inspector Don White Date Dec 11, 2017
 City Works Work Order _____

Building and Grounds

Good Fair Poor Critical N/A

Building Structure	<u>Dog House</u>	Type: <u>POG HOUSE</u>					
Building Roof/Ceiling			☒	☐	☐	☐	☐
Building Finishes	<u>Fiberglass</u>		☒	☐	☐	☐	☐
Building Doors and Windows	<u>NONE</u>		☐	☐	☐	☐	☒
Building HVAC	<u>Vents</u>	Type: <u>Vents</u>	☐	☐	☐	☐	☒
Fencing		Type: <u>Chain link</u>	☒	☐	☐	☐	☐
Gates	<u>4' Pedestrian</u> <u>11' Vehicular</u>	Type: <u>"</u>	☐	☐	☐	☐	☐
Site/Grounds		Size: <u>24' WIDE X 25' DEEP</u>	☒	☐	☐	☐	☐
Lighting	<u>Disconnected</u>		☐	☐	☒	☐	☒
Pavement (Driving)		Type: <u>None</u>	☐	☐	☐	☐	☐
Drainage		Type: <u>Silt over slab</u>	☐	☒	☐	☐	☐
Odor	Comment: <u>NONE</u>		☒	☐	☐	☐	☐
Odor Control System	Type: _____		☐	☐	☐	☐	☐
Odor Control Mechanical			☐	☐	☐	☐	☐
Odor Control Media	Type: _____		☐	☐	☐	☐	☐
Noise			☐	☒	☐	☐	☐
Overall Site Appearance			☐	☒	☐	☐	☐

Comments silt inhibits sliding dog house cover open. slab
flush with natural ground allowing erosion silt to
cover slab. Doghouse center roof beam, sliding
track corroded.

15' / 8'

Structural

			Good	Fair	Poor	Critical	N/A
Wet Well							
	Size:	5 Ft. 0					
	Debris		☐	☐	☐	☒	☐
	Fats, oils, and grease		☐	☒	☐	☐	☐
	Ventilation	None	☐	☐	☐	☐	☒
	Walls	Material: Concrete	☐	☐	☒	☐	☐
	Coatings	Type:	☐	☐	☐	☐	☒
	Access Hatches	Number: 18" man cover	☐	☒	☐	☐	☐
	Slab	concrete	☐	☐	☐	☐	☐
Dry Well/Valve Vault							
	Walls	Material: None	☐	☐	☐	☐	☐
	Coatings	Type:	☐	☐	☐	☐	☐
	Grating/Hatching	Number:	☐	☐	☐	☐	☐
	Stairway/Ladder	Material:	☐	☐	☐	☐	☐
	Sump/Pump	Number:	☐	☐	☐	☐	☐
	Ventilation	Type:	☐	☐	☐	☐	☐

Comments Wet well concrete walls have exposed aggregate
Significant amount of debris in wetwell, 18" man hole
opening impacts proper access.

Mechanical

			Good	Fair	Poor	Critical	N/A
Bypass Connection	(Circle)	YES / NO					
Piping and Valves							
Suction Valve	Number:		☐	☐	☐	☐	☒
Check Valve	Number:	2 DI	☐	☒	☐	☐	☐
Discharge Valve	Number:	2 DI	☐	☒	☐	☐	☐

Mechanical (continued)

			Good	Fair	Poor	Critical	N/A
Corroded	Riser Piping	Material: DI-	☐	☐	☒	☐	☐

Corrosion	Discharge Piping	Material: <u>DF</u>	☐	☐	☒	☐	☐
Corrosion esp. on couplings	Fittings	Material: <u>DF</u>	☐	☐	☒	☐	☐

Comments Valves difficult to access if dog house cannot be completely opened. Return lines from each discharge line to wet well for aeration. Corrosion on bolts, fittings. Discharge pipe goes back through wet well before entering ground as force main.

Pump 1	Asset ID	Make	Model
	Capacity	GPM	
	Impeller Dia./Code	Horsepower	
			Good Fair Poor Critical N/A
	Pump		☐ ☒ ☐ ☐ ☐
	Seals		☐ ☒ ☐ ☐ ☐
	Motor		☒ ☐ ☐ ☐ ☐
	Shaft <u>New</u>		☒ ☐ ☐ ☐ ☐
	Electrical Cable		
	Noise		☐ ☐ ☐ ☐ ☐
	Vibration/Heat		☐ ☐ ☐ ☐ ☐

Pump 1	The following components are to be inspected during pump disassembly	
	Oil	☐ ☒ ☐ ☐ ☐
	Impeller	☐ ☐ ☐ ☐ ☐
	Packing Rings	☐ ☐ ☐ ☐ ☐
	Internal Seals	☐ ☐ ☐ ☐ ☐

oil/grease visible near motors
 Corrosion on motor 2?
 New belts on both pump/motors
 Corrosion on access manhole lid.

Pump 2

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

☐ ☐ ☐ ☐ ☐

Seals

☐ ☐ ☐ ☐ ☐

Motor

CORROSION

☐ ☒ ☐ ☐ ☐

Shaft

☐ ☐ ☐ ☐ ☐

Electrical Cable

Noise

☐ ☒ ☐ ☐ ☐

Vibration/Heat

☐ ☐ ☐ ☐ ☐**Pump 2***The following components are to be inspected during pump disassembly*

Oil

☐ ☒ ☐ ☐ ☐

Impeller

☐ ☐ ☐ ☐ ☐

Packing Rings

☐ ☐ ☐ ☐ ☐

Internal Seals

☐ ☐ ☐ ☐ ☐*Same notes as Pump 1***Pump 3**

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

☐ ☐ ☐ ☐ ☐

Seals

☐ ☐ ☐ ☐ ☐

Motor

☐ ☐ ☐ ☐ ☐

Shaft

☐ ☐ ☐ ☐ ☐

Electrical Cable

Noise

☐ ☐ ☐ ☐ ☐

Vibration/Heat

☐ ☐ ☐ ☐ ☐

Pump 3*The following components are to be inspected during pump disassembly*

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 4

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

	Good	Fair	Poor	Critical	N/A
Pump	☐	☐	☐	☐	☐
Seals	☐	☐	☐	☐	☐
Motor	☐	☐	☐	☐	☐
Shaft	☐	☐	☐	☐	☐
Electrical Cable					
Noise	☐	☐	☐	☐	☐
Vibration/Heat	☐	☐	☐	☐	☐

Pump 4*The following components are to be inspected during pump disassembly*

Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Pump 5

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 5*The following components are to be inspected during pump disassembly*

Oil

Impeller

Packing Rings

Internal Seals

Pump 6

Asset ID _____

Make _____

Model _____

Capacity _____

GPM _____

Impeller Dia./Code _____

Horsepower _____

Good Fair Poor Critical N/A

Pump

Seals

Motor

Shaft

Electrical Cable

Noise

Vibration/Heat

Pump 6

The following components are to be inspected during pump disassembly

	Good	Fair	Poor	Critical	N/A
Oil	☐	☐	☐	☐	☐
Impeller	☐	☐	☐	☐	☐
Packing Rings	☐	☐	☐	☐	☐
Internal Seals	☐	☐	☐	☐	☐

Electrical System

	Good	Fair	Poor	Critical	N/A
Electrical System Power					
Volt/Phase:					
Panel/Enclosures	NEMA4X	YES ? NO	☐	☒	☐
Transformers (AEP)		☐	☐	☐	☐
Disconnect	Type:	could not open panel	☐	☐	☐
Generator	KW	None	☐	☐	☒
Transfer Switch		☐	☐	☐	☒
Electrical System Control					
Breakers	Type:	☐	☐	☐	☐
Speed control/VFD	Type:	☐	☐	☐	☐
Starters	Type:	☐	☐	☐	☐
Control Relays	Type:	☐	☐	☐	☐

Comments CORROSION on panel hinges and closure bolts.

Instrumentation/SCADA

	Good	Fair	Poor	Critical	N/A
Panel					

Instrumentation

Level	Type: <u>ultrasonic</u>	☐	☒	☐	☐	☐
Flow	Type: _____	☐	☐	☐	☐	☐

Instrumentation/SCADA (continued)

	Good	Fair	Poor	Critical	N/A	
PLC	Type: _____	☐	☐	☐	☐	☐
SCADA		☐	☐	☐	☐	☐
RTU	Type: <u>uplink</u>	☒	☐	☐	☐	☐
Radio/ <u>Antenna</u>	Type: <u>small</u>	☒	☐	☐	☐	☐

Comments antenna +/- 6" strapped to control panel power cable, RTU in control panel, NO visual or sound alarm observed

Building and Grounds



Lift Station Perimeter Facing West



Lift Station Perimeter Facing West



Doghouse Facing North



Dog House Slab Flush With Natural Ground

Building and Grounds



Lift Station Dog House Front- Facing East



Lift Station Dog House Rear- Facing East



Electrical and Instrumentation Panel Mounted on Pole- Facing Southwest



Dog House Roof Beam Corrosion

Structural



Wet Well Interior



Wet Well Rim Concrete Deterioration



Significant Debris in Wet Well



Gaps Visible At Points Where Suction Pipes Enter Wet Well

Mechanical



Valves Difficult to Access if Dog House Cannot Be Completely Opened



Pumps, Suction Pipe and Fittings Show Some Corrosion

Electrical & Instrumentation




Electrical and Instrumentation Panel
Mounted on Dog House Rear Wall



Electrical Meter Mounted On Pole

Electrical & Instrumentation



Antenna Strapped to Control Panel Power Cable



Uplink RTU

Basic Pump

DS

Self Priming Centrifugal Pump

Super
T SERIES

VARIOUS PATENTS APPLY

Model T3A3S-B

Size 3" x 3"

**PUMP SPECIFICATIONS****Size:** 3" x 3" (76 mm x 76 mm) NPT - Female.**Casing:** Gray Iron 30.

Maximum Operating Pressure 86 psi (593 kPa).*

Semi-Open Type, Two Vane Impeller: Ductile Iron 65-45-12.

Handles 2 1/2" (63,5 mm) Diameter Spherical Solids.

Impeller Shaft: Alloy Steel 4150.**Shaft Sleeve:** Alloy Steel 4130.**Replaceable Wear Plate:** Carbon Steel 1015.**Removable Adjustable Cover Plate:** Gray Iron 30; 35 lbs. (16 kg)**Seal Plate:** Gray Iron 30.**Flap Valve:** Neoprene ^w/Nylon and Steel Reinforcing.**Bearing Housing:** Gray Iron 30.**Radial and Thrust Bearings:** Open Single Row Ball.**Bearing and Seal Cavity Lubrication:** SAE 30 Non-Detergent Oil.**Flanges:** 125# Gray Iron 30.**Gaskets:** Buna-N ^w/Compressed Synthetic Fibers, Vegetable Fiber, PTFE, Cork and Rubber.**O-Rings:** Buna-N.**Hardware:** Standard Plated Steel.**Brass Pressure Relief Valve.****Bearing and Seal Cavity Oil Level Sight Gauges.****Optional Equipment:** Automatic Air Release Valve. Metal

Bellows Seal. 120V/240V Casing Heater. High Pump

Temperature Shutdown Kit. G-R Hard Iron Casing.

Self-Cleaning Wear Plate.

Gray Iron 30 Suction and Discharge Spool Flanges:

3" ASA (**Specify Model T3A3S-B /F**).80 mm DIN 2527 (PN 16) (**Specify Model T3A3S-B /FM**).



*Consult Factory for Applications Exceeding Maximum Pressure and/or Temperature Indicated.



Shown with Optional Suction and Discharge Spool Flanges (Available in ASA or DIN Standard Sizes).

SEAL SPECIFICATIONS

Cartridge Type, Mechanical, Oil-Lubricated, Double Floating, Self-Aligning. Tungsten Titanium Carbide Rotating and Stationary Faces. Stainless Steel 316 Stationary Seat. Fluorocarbon Elastomers (DuPont Viton[®] or Equivalent). Stainless Steel 18-8 Cage and Spring. Maximum Temperature of Liquid Pumped, 160°F (71°C).*

SEAL DETAIL

THE GORMAN-RUPP COMPANY • MANSFIELD, OHIO

GORMAN-RUPP OF CANADA LIMITED • ST. THOMAS, ONTARIO, CANADA


www.grpumps.com

Specifications Subject to Change Without Notice


Printed in U.S.A.

SECTION 55, PAGE 2000

NET WEIGHT:	404 LBS. (183 KG.)*
SHIPPING WEIGHT:	452 LBS. (205 KG.)*
EXPORT CRATE:	19.3 CU. FT. (0,55 CU. M.)
*ADD 10 LBS. (4.5 KG.) ^W/EACH SPOOL FLANGE	



T3AS-B



GORMAN-RUPP OF CANADA LIMITED • ST. THOMAS, ONTARIO, CANADA

Specifications Subject to Change Without Notice

Printed in U.S.A.