


NOTES:

1. ONE PIER TO BE INSTALLED BEHIND BELL ON EACH JOINT OF DUCTILE IRON PIPE SUSPENDED IN AIR.
2. ALL PIERS OVER 3' IN HEIGHT SHALL BE REINFORCED WITH #4 BARS 12" O.C.
3. CONCRETE SHALL BE 3,000 PSI (CLASS A) CONCRETE.



**CITY OF TYLER**  
STANDARD DETAIL

**CONCRETE PIER**

REVISION DATE:  
MAY 14, 2021