


P. O. Box 2039
Tyler, Texas 75710



511 W. Locust
Tyler, Texas 75702

22 April 2022

Associate Director, Water Enforcement Branch
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

James Sallans
Litigation Division, MC-175
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087


Re: City of Tyler Consent Decree
DOJ No. 90-5-1-1-09767
Quarterly Report – 2022 Quarter 1 (January – March)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 January 2022 through 31 March 2022.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,



Douglas Box
Interim Director of Utilities

Enclosures

Start Date	Start Time	Finish Date	Finish Time	Address	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
1/1/2022	10:25:37 AM	1/1/2022	1:25:47 PM	5421 O'Neil Creek Dr. Tyler, TX, 75703	SS.GM.T0002782	West Mud Creek	600	550	GRAVITY MAIN	BREAKS, DUE TO EROSION BREAKS, OTHER CAUSES FLOODING	No	No	Overflow Vacuumed, Overflow Stopped, Repaired	Repair Sewer Main	No
1/6/2022	8:24:00 AM	1/6/2022	8:44:00 AM	2454 W Front St. Tyler, TX, 75702	SS.GM.T0013941	Willow Creek	100	77	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/21/2022	8:08:00 AM	1/21/2022	8:30:00 AM	W 32nd St & Border Ave. Tyler, TX, 75702	SS.GM.T0005348	Contained in Yard	66	50	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Repair Manhole/Invert	No
2/11/2022	5:40:00 PM	2/11/2022	6:00:00 PM	422 Boyd Ln. Tyler, TX, 75703	SS.GM.T0001053	Contained in Storm Drain	40	40	MANHOLE	DEBRIS, FATS, OIL, GREASE	No	Yes, 2/8/2019	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
2/16/2022	9:40:46 AM	2/16/2022	11:42:58 AM	1308 W 33rd St. Tyler, TX, 75702	SS.GM.T0002864	Black Fork Creek	3660	2000	MANHOLE	CONTRACTOR DAMAGE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Advised contractor to use ice bypass pumps.	No
2/22/2022	2:30:00 PM	2/23/2022	12:00:00 AM	302 N Fleisher Ave. Tyler, TX, 75702	SS.GM.T0004187	Black Fork Creek	5,700	2,000	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Spill Contained, Overflow Stopped, Area Disinfected	After a series of three repairs from contractor damage, it was determined the SSO was caused by a faulty private lateral	No
2/25/2022	12:29:00 PM	2/25/2022	1:29:00 PM	6117 W Dobbs St. Tyler, TX, 75701	SS.GM.T0007078	Contained in Street	360	300	MANHOLE	BREAKS, OTHER CAUSES	No	No	Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/1/2022	4:47:30 PM	3/1/2022	5:47:00 PM	1904 Lamplight Ln. Tyler, TX, 75701	SS.GM.T0004741	Black Fork Creek	600	550	MANHOLE	BREAKS, OTHER CAUSES	No	No	Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/10/2022	3/10/2022	3/11/2022	10:00:00 AM	1630 Old Oman Rd. Tyler, TX, 75701	SS.GM.T0008566	Black Fork Creek	2520	2000	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Repair Manhole / Invert	No
3/20/2022	11:43:00 AM	3/20/2022	12:45:00 PM	Sheandoah Dr. & McDonald Rd. Tyler, TX, 75701	SS.GM.T0004626	Black Fork Creek	248	200	MANHOLE	ROOTS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No
3/29/2022	9:20:00 AM	3/29/2022	10:00:00 AM	608 E 5th St. Tyler, TX, 75701	SS.GM.T0014175	Black Fork Creek	400	350	MANHOLE	ROOTS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No
3/29/2022	10:25:00 AM	3/29/2022	11:25:26 AM	1527 E Commerce St. Tyler, TX, 75702	SS.GM.T0013267	Black Fork Creek	600	300	MANHOLE	ROOTS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage this system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

Douglas Box - General Director of Utilities

4/22/2022