


P. O. Box 2039  
Tyler, Texas 75710



511 W. Locust  
Tyler, Texas 75702

09 January 2023

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087

Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-1-09767  
Quarterly Report – 2022 Quarter 4 (October – December)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 October 2022 through 31 December 2022.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

Katherine Dietz, P.E.  
Director of Utilities

Enclosures

Start Date	Start Time	Finish Date	Finish Time	Address/Location	Asset ID	Receiving Stream	Estimated Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
10/3/2022	12:42:00 PM	10/3/2022	1:30:06 PM	4048 Charleston Park, Tyler, TX, 75701	SS.GM.T0012643	Contained in Street	12	12	PRIVATE CLEANOUT	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
10/7/2022	10:00:21 AM	10/7/2022	3:00:27 PM	Kent Dr & Reed Rd, Tyler, TX, 75707	SS.FM.T000056	Contained in Yard	1,500	1,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	Yes, 5/26/2017 & 9/30/2020	Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
10/12/2022	4:55:00 PM	10/12/2022	5:10:00 PM	1923 Woodlawn St, Tyler, TX 75702	SS.GM.T007369	Contained in Yard	45	30	PRIVATE CLEANOUT	DEBRIS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
10/15/2022	9:40:15 AM	10/15/2022	10:25:23 AM	2505 McDonald Rd, Tyler, TX, 75701	SS.GM.T004626	Black Fork Creek	225	190	MANHOLE	DEBRIS	No	Yes, 1/18/2019 & 3/20/2022	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
10/15/2022	9:00:00 AM	10/15/2022	1:30:00 PM	10265 Greenbriar Rd, Tyler, TX, 75709	SS.FM.T000042	Indian Creek	26,098	2,000	FORCE MAIN	BREAKS, OTHER CAUSES	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Place on High Frequency Cleaning List	No
10/19/2022	8:35:57 AM	10/19/2022	9:00:03 AM	3217 Rolling Hill Dr, Tyler, TX, 75702	SS.GM.T0007602	Contained in Yard	50	40	MANHOLE	DEBRIS	No	Yes, 12/5/2017 & 7/13/2021	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Place on High Frequency Cleaning List	No
10/20/2022	11:30:28 AM	10/20/2022	12:30:32 PM	4430 Chandler Hwy, Tyler, TX, 75709	SS.GM.T0006964	Contained in Yard	300	260	MANHOLE	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Force Main	No
11/2/2022	10:10:06 AM	11/2/2022	10:35:13 AM	1024 W 4th St, Tyler, TX 75701	SS.GM.T0000501	Contained in Storm Drain	250	210	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Place on Root Control Program	No
11/2/2022	1:50:53 PM	11/2/2022	2:30:58 PM	Roseland Blvd & E 5th St, Tyler, TX, 75701	SS.GM.T0006105	Contained in Street	80	70	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
11/7/2022	11:23:28 AM	11/7/2022	12:05:34 PM	723 N Bois D Arc Ave, Tyler, TX 75702	SS.GM.T0008499	Contained in Street	21	20	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
12/1/2022	12:50:26 PM	12/1/2022	2:00:30 PM	Rice Rd & Old Bullard Rd, Tyler, TX, 75703	SS.GM.T0001294	West Mud creek	700	640	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Refer to FOG Program	No
12/27/2022	8:39:00 AM	12/27/2022	10:39:00 AM	Clinic Dr & Hospital Dr, Tyler, TX 75703	SS.GM.T0014216	Black Fork Creek	480	400	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Repair Manhole/Invert & Repair Sewer Main	No
12/31/2022	5:00:32 PM	12/31/2022	5:40:39 PM	N Fannin Ave & E Berta St, Tyler, TX, 75702	SS.GM.T0007030	Contained	80	80	MANHOLE	ROOTS	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on Root Control Program	No

**CERTIFICATION:**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

  
Katherine Delt, Director of Utilities

  
Date  
1/19/2023