


P. O. Box 2039  
Tyler, Texas 75710



511 W. Locust  
Tyler, Texas 75702

10 April 2023

Associate Director, Water Enforcement Branch  
Compliance Assurance and Enforcement Division  
U.S. Environmental Protection Agency, Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

James Sallans  
Litigation Division, MC-175  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, TX 78711-3087

Re: City of Tyler Consent Decree  
DOJ No. 90-5-1-09767  
Quarterly Report – 2023 Quarter 1 (January – March)

To EPA Region 6 and TCEQ:

Pursuant to Paragraph IX.87 of the Consent Decree for *United States et al v. City of Tyler*, please find enclosed electronic and hard copies of the City of Tyler's quarterly report covering the time period of 1 January 2023 through 31 March 2023.

Please do not hesitate to contact me at (903) 531-1234 if you have any questions.

Sincerely,

*Katherine M Dietz*

Katherine Dietz, P.E.  
Director of Utilities

Enclosures

Start Date	Start Time	Finish Date	Finish Time	Address	Asset ID	Receiving Stream	Estimated Volume Discharged (gal)	Estimated Volume Recovered (gal)	Component from Which SSO Was Released	Suspected Cause of SSO	Potential Danger to Human Health & Safety or the Environment	Repeat SSO? If yes, list date(s) of previous SSO(s) at this address/asset	Comments/Response	Follow-Up Actions	Public Notification Made?
1/1/2023	11:40:30 AM	1/1/2023	12:40:39 PM	E Line St & N Beverly Ave, Tyler, TX 75702	SS.GM.T0004844	Black Fork Creek	180	100	MANHOLE	FATS, OIL, GREASE	No	Yes, 4/5/2017, 12/27/2017, 3/4/2021, 8/29/2021	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/3/2023	11:50:59 AM	1/3/2023	12:10:13 PM	1800 Border Ave, Tyler, TX 75702	SS.GM.T0008093	Contained in Street	20	15	GRAVITY MAIN	BREAKS, OTHER CAUSES FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Replace Sewer Main	No
1/3/2023	3:00:00 PM	1/3/2023	3:30:06 PM	3083 Tenneha Ave, Tyler, TX 75702	SS.GM.T0015525	Contained in Street	300	270	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/4/2023	12:20:07 PM	1/4/2023	12:40:40 PM	1814 Roseland Blvd, Tyler, TX 75701	SS.GM.T0006109	Contained in Street	100	80	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/10/2023	12:07:00 PM	1/10/2023	1:07:00 PM	1600 W Southwest Loop 323, Tyler, TX 75701	SS.GM.T0002514	Contained in Culvert	240	200	PRIVATE CLEANOUT	UNDETERMINED	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/14/2023	11:36:00 AM	1/14/2023	12:06:00 PM	W 10th St & S Vine Ave, Tyler, TX 75701	SS.GM.T0009334	Contained in Storm Drain	90	80	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/17/2023	12:50:50 PM	1/17/2023	1:30:55 PM	5403 S Broadway Ave, Tyler, TX 75703	SS.GM.T0002424	West Mud Creek	400	300	MANHOLE	DEBRIS FATS, OIL, GREASE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/17/2023	1:20:09 PM	1/17/2023	1:40:29 PM	Devine St & Golden Rd, Tyler, TX 75701	SS.GM.T0015454	Contained in Street	60	40	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/20/2023	11:25:04 AM	1/20/2023	11:40:13 PM	1118 W Gentry Pkwy, Tyler, TX 75702	SS.GM.T0007495	Contained in Storm Drain	45	30	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/23/2023	3:03:02 PM	1/23/2023	3:23:22 PM	1828 E Southeast Loop 323, Tyler, TX 75701	SS.GM.T0001241	Contained in Street	60	45	PRIVATE CLEANOUT	FATS, OIL, GREASE	No	Yes, 1/11/2017	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
1/25/2023	12:35:08 PM	1/25/2023	12:50:13 PM	Hubbard Dr & New Copeland Rd, Tyler, TX 75703	SS.GM.T0003032	Contained in Yard	125	100	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
1/25/2023	2:30:56 PM	1/25/2023	2:44:03 PM	2001 E Southeast Loop 323, Tyler, TX 75701	SS.GM.T0001250	Contained in Street	28	20	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List, Treated for FOG, Refer to Pre-treatment and Reached out to Restaurants Regarding FOG	No
2/1/2023	12:30:53 PM	2/1/2023	12:40:59 PM	751 W 32nd St, Tyler, TX 75702	SS.GM.T0008165	Contained in Storm Drain	200	160	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
2/5/2023	1:50:51 PM	2/5/2023	2:30:56 PM	Cambridge Rd & Harvard Dr, Tyler, TX 75703	SS.GM.T0001843	Contained in Street	40	30	MANHOLE	FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning list	No
2/6/2023	10:30:56 AM	2/6/2023	1:10:02 PM	Alexandria Pl & Fairfax Dr, Tyler, TX 75701	SS.GM.T0009284	Black Fork Creek	3200	2000	GRAVITY MAIN	BREAKS DUE TO EROSION	No	Yes, 5/2/2020, 11/13/2020	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
2/21/2023	9:00:35 AM	2/21/2023	5:00:39 PM	3931 Troup Hwy, Tyler, TX 75703	SS.GM.T0013366	West Mud Creek	4800	2500	GRAVITY MAIN	BREAKS, OTHER CAUSES	No	Yes, 12/13/2018	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
2/24/2023	6:00:00 AM	2/24/2023	6:30:00 AM	625 E Rieck Rd, Tyler, TX 75703	SS.GM.T0001493	Contained in Street	60	45	MANHOLE	OTHER - VANDALISM	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Removed Obstruction from Main	No
2/27/2023	4:10:14 PM	2/27/2023	4:20:20 PM	707 N Englewood Ave, Tyler, TX 75702	SS.GM.T0005901	Contained in Yard	20	15	PRIVATE CLEANOUT	BREAKS, OTHER CAUSES	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/5/2023	12:30:08 PM	3/5/2023	1:30:12 PM	617 W Dobbs St, Tyler, TX 75701	SS.MH.T0003298	Contained in Street	180	120	MANHOLE	EQUIPMENT MALFUNCTION	No	Yes, 2/25/2022	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Scheduled a 24 hr Pump Watch	No
3/9/2023	12:40:13 PM	3/9/2023	1:10:21 PM	1315 Carlyle Ave, Tyler, TX 75702	SS.GM.T0005148	Black Fork Creek	60	45	GRAVITY MAIN	CONTRACTOR DAMAGE	No	No	Main Jetted, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/13/2023	11:20:31 AM	3/13/2023	12:10:36 PM	707 N Englewood Ave, Tyler, TX 75702	SS.GM.T0005901	Contained in Yard	25	0	MANHOLE	BREAKS, OTHER CAUSES	No	Yes, 2/27/2023	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/15/2023	7:45:40 AM	3/15/2023	8:15:47 AM	2508 Walton Rd, Tyler, TX 75701	SS.GM.T0007257	Contained in Storm Drain	150	135	MANHOLE	DEBRIS FATS, OIL, GREASE	No	Yes, 3/2/2021	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
3/14/2023	12:00:00 PM	3/14/2023	1:00:00 PM	5617 Plantation Dr, Tyler, TX 75703	SS.GM.T0001130	Contained in Yard	300	0	MANHOLE	BREAKS, OTHER CAUSES	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared, Repaired	Repair Sewer Main	No
3/31/2023	10:15:43 AM	3/31/2023	11:00:48 AM	3812 CR 427, Tyler, TX 75704	SS.GM.T0012075	Contained in Yard	90	60	MANHOLE	DEBRIS FATS, OIL, GREASE	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency Cleaning List	No
3/31/2023	2:00:13 PM	3/31/2023	2:40:18 PM	630 S Chilton Ave, Tyler, TX 75701	SS.GM.T0005120	Contained in Street	80	64	MANHOLE	DEBRIS	No	No	Main Jetted, Spill Contained, Overflow Vacuumed, Overflow Stopped, Area Disinfected, Blockage Cleared	Place on High Frequency cleaning List	No

CERTIFICATION:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possibility of fine and imprisonment for knowing violations.

Katherine M Dietz

04-11-23

Katherine Dietz, P.E. - Director of Utilities

Date